

# **PoKeys protocol specification**

Copyright PoLabs 2008-2016  
All rights reserved

Version: 6.3.2016

Compatible PoKeys firmware versions:

PoKeys55: **2.1.23**

PoKeys56: **3.1.68**

PoKeys57: **4.1.57**

## Brief protocol description

### USB

PoKeys55/PoKeys56U are USB HID devices that use OS's integrated drivers to communicate with software. No additional drivers are necessary to communicate with devices.

PoKeys55/PoKeys56U use these Vendor and Product IDs:

idVendor: 0x1DC3

idProduct: 0x1001

The device encapsulates three interfaces, first (index 0) being standard USB HID keyboard, second (index 1) being PoKeys communication interface and the third (index 2) standard USB HID Joystick.

Configuration is set or read using the second interface. On Windows host the PoKeys device is found by searching among connected HID devices and looking their PathNames. If the PathName contains `hid#vid_1dc3&pid_1001&mi_01`, this is the correct interface to PoKeys device. If more than one PoKeys device is connected to the same host, differentiation at this level is impossible, so user ID byte must be read from the PoKeys device. USB serial numbers can be used to differentiate between devices. PoKeys56U device reports serial number in the format of `xxxxx.2` (where `xxxxx` is the serial number of the PoKeys device).

In PoKeys communication DLL, request are handled this way:

1. send report with a unique request ID (simply ever-increasing value)
2. read report
3. check Request ID, if it does not match the one in (1), sleep for 1 ms and then go to (2) (try this 5 times, then terminate)
4. check packet checksum, if it does not match go to (1) (try this 2 times, then terminate)

### Communication

To ensure a highest possible compatibility with USB PoKeys devices, PoKeys56E uses Extended packet mode as described below. Packets are transferred with TCP protocol.

### Network edition

PoKeys56E uses a combination of UDP and TCP packets to communicate with the host. Both use a port number 20055.

### Device discovery

PoKeys56E modules are discovered via broadcast UDP packets. A host sends out a UDP packet with a broadcasting address. All PoKeys56E devices respond with another UDP packet that contains the device's identification (User ID, serial number, version) and its IP address. At the same time, if device is configured to use DHCP server and no DHCP server responded to the request, PoKeys56E will use the temporary address of `x.x.x.250`, where `x.x.x` is the subnet address of the computer that the request was sent from (with `255.255.255.0` subnet mask).

Packet data is formatted the following way:

Host -> device: empty packet (ignored)

Device -> host

- byte 1: User ID number
- bytes 2,3: Serial number
- bytes 4,5: Version
- bytes 6,7,8,9: IP address

### Communication

All further communication with the device is accomplished with TCP or UDP connection on port 20055. Packet structure is 64-bytes long and is described below as Extended packet mode.

## *Security*

PoKeys56E supports additional security option that requires the user to enter the password before the access to the device is granted. The password can contain any character and can be up to 32 characters long.

## *Connection timeout*

After 3 seconds of inactivity (or otherwise specified in the configuration), PoKeys56E terminates the TCP connection with the host (except for Modbus, where connection timeout is settable by user).

## **Packet formatting**

Incoming and outgoing packets are 64 bytes long. Basic packets use only first 8 bytes. Extended packets use the whole packet.

Host>Device

- byte 1: control 0xBB
- byte 2: operation
- byte 3-6: operation parameters
- byte 7: request ID
- byte 8: control byte (sum after mod 0x100)

Device>Host

- byte 1: control 0xAA
- byte 2: operation
- byte 3-6: operation parameters
- byte 7: request ID
- byte 8: control byte (sum after mod 0x100)

Extended packet mode (supported since version 1.8)

Packet size is increased to 64 bytes. First 8 bytes remain the same, additional 56 bytes are used for extended mode. Reserved bytes should be set to 0.

## PoKeys devices

PoKeys devices are described using three descriptors:

- PoKeys device series
- PoKeys device hardware version
- PoKeys device firmware type

### Overview

Series ID	Hardware ID	Hardware version	Firmware type IDs supported
0	0	unsupported device type or old firmware	0 (default)
55	1,2,3	PoKeys55	0 (default)
56	10	PoKeys56U	0 (default) 1 (PoTLog27U)
56	11	PoKeys56E	0 (default) 1 (PoTLog27E)
57	28	PoKeys57U	0 (default)
57	29	PoKeys57E	0 (default)
57	30	PoKeys57Uv1.1	0 (default)
57	31	PoKeys57Ev1.1	0 (default)
57	32	PoKeys57CNC	0 (default)
57	35	PoKeys57U OEM	0 (default)
57	36	PoKeys57E OEM	0 (default)
57	37	PoPLC57NG	0 (default)
57	38	PoKeys57CNCdb25	0 (default)
58	40	PoKeys58EU	0 (default)
58	41	PoBootload (series 58)	0 (default)
58	50	PoPLC v1.0	0 (default)
16	60	PoKeys16	0 (default)

### Device series

#### Series 55

Series 55 contains PoKeys55 device only. The support for this series is limited.

Device	HW ID	Device features
PoKeys55	0	USB keyboard/joystick, 55x I/O, 5x 10-bit analog input, 1x 10-bit analog output, 6x PWM, 25x encoders, 3x fast encoders, 2x Matrix LED, 16x8 Matrix keyboard, LCD, PoExtBus

#### Series 56

Series 56 contains PoKeys56U and PoKeys56E devices

Device	HW ID	Device features
PoKeys56U	10	USB keyboard/joystick, 55x I/O, 24x digital counter, 7x 12-bit analog input, 6x PWM, 25x encoders, 3x fast encoders, 1x ultra-fast encoder, 2x Matrix LED, 16x8 Matrix keyboard, LCD, PoExtBus, PoNET, I <sup>2</sup> C and 1-wire buses support, PoIL core (4k program memory, 1k data memory)
PoKeys56E	11	Ethernet connectivity, web interface, Modbus TCP, server reports, 55x I/O, 24x digital counter, 7x 12-bit analog input, 6x PWM, 25x encoders, 3x fast encoders, 1x ultra-fast encoder, 2x Matrix LED, 16x8 Matrix keyboard, LCD, PoExtBus, PoNET, I <sup>2</sup> C and 1-wire buses support, PoIL core (4k program memory, 1k data memory)

### *Series 57*

Series 57 contains PoKeys57E device

Device	HW ID	Device features
PoKeys57E	31	Ethernet connectivity, web interface, Modbus TCP, server reports, 55x I/O, 24x digital counter, 7x 12-bit analog input, 6x PWM, 25x encoders, 3x fast encoders, 1x ultra-fast encoder, 2x Matrix LED, 16x8 Matrix keyboard, LCD, PoExtBus , PoNET, I <sup>2</sup> C and 1-wire buses support, PoIL core (32k program memory, 4k data memory)

### *Series 58*

Series 58 contains PoPLC v1.0 and PoKeys58EU

**TBD**

## Supported commands:

Brief protocol description .....	2
USB .....	2
Communication .....	2
Network edition .....	2
Device discovery .....	2
Communication .....	2
Security .....	3
Connection timeout .....	3
Packet formatting .....	3
PoKeys devices.....	4
Overview .....	4
Device series.....	4
Series 55.....	4
Series 56.....	4
Series 57.....	5
Series 58.....	5
Supported commands: .....	6
Supported functions.....	12
General .....	15
Read device data .....	15
Set user ID.....	15
Read user ID (deprecated, use »Read device data« instead ).....	15
Read build date (deprecated, use »Read device data« instead ).....	16
Configuration saving .....	17
Configuration saving and lock.....	17
Configuration reset .....	17
Get system load status.....	17
Get tick counter .....	18
Read/activate option .....	18
Enable/disable fast USB interface .....	18
Delayed startup configuration .....	18
General pin settings.....	21
Set input/output settings.....	21
Read input/output settings.....	21
Input/output settings - extended mode .....	22

Additional settings .....	23
Key association setting (for pins which are set to 1, 2 or 32) .....	24
Reading of key associations .....	24
Typematic delay setup .....	25
Key repeat rate setup.....	25
Key mappings .....	26
Key codes .....	26
Key modifiers .....	26
Triggered input key mappings.....	27
Get/Set Connection signal pin status.....	28
Encoder settings.....	29
Encoder key mapping for direction A.....	29
Encoder key mapping for direction B.....	29
Read encoder settings.....	30
Read encoder key mapping for direction A .....	30
Read encoder key mapping for direction B.....	30
Read encoder RAW value.....	31
Reset encoder RAW value.....	31
Encoder option.....	31
Encoder channel A and B pin .....	32
Encoder channel A key code and modifier .....	32
Encoder channel B key code and modifier.....	33
Get encoder long RAW values.....	33
Enable/disable fast encoders on pins 1-2, 3-4 / 5-6 and 15-16.....	35
Enable/disable ultra fast encoder .....	36
Digital counters .....	37
Get digital counters values.....	37
Get/Set digital counter direction pins.....	37
Reset digital counters values .....	37
I/O operations .....	39
Reading of inputs .....	39
Block inputs reading.....	39
Block inputs reading - part 2 .....	39
Analog inputs .....	40
Analog inputs reading: .....	40
Analog inputs block reading - 4x 8bit.....	40
Analog inputs block reading - 3x 10bit.....	40

Analog inputs reading – all analog inputs in one command .....	41
Get analog RC filter value.....	41
Set analog RC filter value .....	41
Outputs setting .....	42
Block outputs writing .....	42
Analog outputs settings.....	42
Get device status (extended mode - IO, analog, encoders).....	42
Joystick settings.....	44
Read joystick configuration.....	44
Set joystick configuration.....	44
Get joystick up Event buttons configuration .....	44
Set joystick up Event buttons configuration .....	45
Set/Get joystick analog to digital key mapping options.....	45
Macros.....	48
Create macro.....	48
Modify macro.....	48
Delete macro.....	48
Save macros to flash .....	49
Rename macro .....	49
Transfer macro.....	50
Get macro length .....	50
Get macro name .....	50
Get macro keys .....	51
Get free space .....	51
Get active macros .....	52
Set/Get macro name and length.....	52
Set/Get macro keys.....	52
Matrix keyboard .....	54
Get/Set matrix keyboard configuration .....	54
PWM channels.....	55
Get/set PWM configuration.....	55
LCD displays.....	56
Set LCD configuration.....	57
LCD operation .....	57
Matrix LED display operations.....	59
Get/set Matrix LED display configuration .....	59
Update matrix LED display .....	59

PoExtBus functionality.....	60
Set PoExtBus settings.....	60
I <sup>2</sup> C communication bus.....	62
I <sup>2</sup> C settings and communication .....	62
PoNET – »PoI2C« commands .....	64
PoNET settings and communication .....	64
kbd48CNC specifics: .....	66
SPI communication bus .....	67
SPI settings and communication .....	67
1-wire communication bus.....	68
1-wire settings and communication .....	68
Real-Time mode (experimental, not implemented in current release) .....	71
RTmode – setup .....	71
RTmode – set/get data .....	71
Network settings .....	73
Get/set network configuration .....	73
Get security setting status .....	74
Authorise user.....	74
Set user password.....	74
Modbus settings.....	75
Get/set modbus settings.....	76
Web interface.....	77
Setup web interface settings .....	77
User accounts .....	77
Setup user account .....	77
Dashboard items .....	77
Setup dashboard items .....	79
Dashboard items (series 57).....	80
0x78/0x00 Dashboard item operation .....	81
0x78/0x80 Custom unit operation .....	82
Sensor list (only for PoKeys56E/PoKeys56U) .....	83
Setup sensors.....	83
Read all sensors.....	84
PoKeys EasySensors (PoKeys series 57).....	85
0x76 Read / write sensors setup (series 57) .....	86
0x77 Read sensors values (series 57).....	87
Cosm support settings (deprecated in 3.0.39 firmware).....	89

Cosm settings .....	89
Server reports settings .....	90
Server reports settings .....	91
Pulse engine commands (not supported since FW version 3.0.66) .....	94
Constants used .....	94
Get status (position, limits, home, ...) .....	94
Set current position .....	95
Set current pulse engine state .....	95
Set MPG jogging options .....	96
Set reference position .....	96
Enable/disable pulse engine (read with command 0x80, 0x00) .....	97
Get parameters .....	97
Set parameters .....	97
Get axes parameters .....	98
Set axes parameters .....	98
Get controller setup .....	99
Set CNC keyboard setup .....	99
Execute homing .....	99
Get engine info .....	99
Fill buffer .....	100
Clear buffer .....	100
Get buffer size .....	101
Pulse engine commands v2 .....	103
Constants used .....	103
0x85/0x00 Get status (position, limits, home, ...) .....	105
0x85/0x01 Setup pulse engine .....	106
0x85/0x02 Set state .....	107
0x85/0x03 Set axis position .....	107
0x85/0x04 Set outputs .....	108
0x85/0x05 Reboot pulse engine .....	109
0x85/0x10 Get axis configuration .....	113
0x85/0x11 Set axis configuration .....	114
0x85/0x20 Move (Set reference position or speed) .....	116
0x85/0x21 Start homing .....	116
0x85/0x22 Finish homing .....	117
0x85/0x23 Start probing .....	117
0x85/0x24 Finish probing .....	118

0x85/0xF0 Clear motion buffer .....	118
0x85/0xFF Fill motion buffer - 8-bit mode (max. 127 steps per slot) .....	119
0xB0/0x85 Fill motion buffer via multi-part packet .....	120
0x85/0xE0 Transfer RAW data .....	121
0x85/0x90 Read smart pulse generator configuration .....	121
0x85/0x91 Configure smart pulse generator .....	122
0x85/0x92 Reset smart pulse generator counters .....	122
0x85/0x95 Read smart pulse generator status .....	123
0x85/0x96 Read smart pulse generator encoder positions .....	124
Failsafe mode .....	137
Basic settings .....	137
PoIL commands .....	138
0x82/0x00 PoIL core status .....	138
0x82/0x01 Set PoIL core state .....	138
0x82/0x02 Reset PoIL processor .....	139
0x82/0x03 Set PoIL master enable status .....	139
0x82/0x05 Set PoIL debug mode .....	139
0x82/0x10 PoIL memory read .....	140
0x82/0x11 PoIL memory read – monitor mode .....	140
0x82/0x15 PoIL memory write .....	141
0x82/0x16 PoIL memory erase .....	141
0x82/0x20 PoIL task status read .....	142
RTC (Real Time Clock) setup .....	143
Read/Set current time .....	143
System event logging .....	145
Read/clear system log .....	145
PPM decoder configuration and status .....	146
PPM decoder configuration and status .....	146

## Supported functions

0x00 - Read serial number, version  
0x02 - Set User ID  
0x03 - Read User ID and lock setting  
0x04 - Read build date  
0x05 - Get system load status  
0x06 - Read device name  
0x07 - Enable/disable fast USB interface  
0x08 - Delayed startup setup  
0x09 - PPM decoder configuration and status  
0x0A - Session settings  
0x0B - Misc USB device configuration  
0x10 - Set pin function  
0x11 - Set encoder settings  
0x12 - Set encoder key mapping for direction A  
0x13 - Set encoder key mapping for direction B  
0x15 - Get pin function  
0x16 - Get encoder settings  
0x17 - Get encoder key mapping for direction A  
0x18 - Get encoder key mapping for direction B  
0x19 - Get encoder RAW value  
0x1A - Reset encoder RAW value  
0x1B - Get/Set Connection signal pin status  
0x1C - Enable/Disable Ultra fast encoder input  
0x1D - Reset digital counters values  
0x1E - Additional pin settings  
0x1F - Get pin capabilities  
0x20 - Set key association  
0x25 - Get key association  
0x30 - Get input  
0x31 - Block get input I  
0x32 - Block get input II  
0x35 - Get analog input  
0x36 - Block get analog (4x 8bit)  
0x37 - Block get analog (3x 10bit)  
0x38 - Get analog RC filter value  
0x39 - Set analog RC filter value  
0x3A - Get all analog inputs (7x 12bit on PoKeys56) – extended mode  
0x40 - Set output  
0x41 - Set analog output  
0x42 - Block set output I  
0x43 - Block set output II  
0x4A - MCS system  
0x50 - Save configuration  
0x51 - Save and lock configuration  
0x52 - Disable lock and reset configuration  
0x60 - Get joystick configuration  
0x61 - Get joystick up Event buttons configuration  
0x65 - Set joystick configuration

0x66 - Set joystick up Event buttons configuration  
0x6A - Set joystick analog to digital mapping

0x70 - Setup sensors (PoKeys series 56)  
0x71 - Setup dashboard items  
0x72 - Setup web users  
0x73 - Setup web settings  
0x74 - Read all sensors  
0x75 - Reserved  
0x76 - Setup sensors (PoKeys series 57)  
0x77 - Read sensor values (PoKeys series 57)  
0x78 - Setup dashboard items (PoKeys series 57)  
0x80 - Pulse engine commands - deprecated since 3.1.0  
0x81 - Failsafe settings  
0x82 - PoIL commands  
0x83 - RTC settings  
0x84 - System log operations  
0x85 - Pulse engine commands - v2

0x8F - Unlock option

0x90 - Create macro  
0x91 - Modify macro  
0x92 - Delete macro  
0x93 - Save macros to flash  
0x94 - Rename macro  
0x95 - Transfer macro  
0x96 - Get macro length  
0x97 - Get macro name  
0x98 - Get macro keys  
0x99 - Get free space  
0x9A - Get active macros

0xB0 - Multi-part packet

0xC0 - Pin configuration  
0xC1 - Pin key mapping  
0xC2 - Pin key codes  
0xC3 - Pin key modifiers  
0x21 - Pin typematic delay  
0x22 - Pin repeat rate  
0xC4 - Encoder option  
0xC5 - Encoder channel A + B  
0xC6 - Encoder channel A key code + modifier  
0xC7 - Encoder channel B key code + modifier  
0xCD - Get encoder long RAW values  
0xCE - Enable fast encoders for pins 1-6  
0xC8 - Get macro name and length  
0xC9 - Get macro keys

0xCA - Matrix keyboard configuration

0xCB - PWM configuration

0xCC - Get device status (IO, analog, encoders)

0xCD - Get 32-bit RAW encoder data

0xCE - Enable/disable Fast encoders

0xCF - Get tick counter

0xD0 - LCD configuration

0xD1 - LCD operation

0xD5 - Matrix LED configuration

0xD6 - Matrix LED update

0xD7 - Triggered input settings

0xD8 - Digital counters values

0xD9 - (Set/Get) Digital counters direction pins

0xDA - set auxiliary bus settings

0xDB - I<sup>2</sup>C settings and communication

0xDC - 1-wire settings and communication

0xDD - I2C communication

0xDE - UART communication

0xE0 - Get/set network settings

0xE1 - Get security setting status (and password hash seed)

0xE2 - Authorise user

0xE3 - Set user password

0xE4 - Get/Set Modbus settings

0xE5 - SPI communication

0xEF - Get/set Cosm settings

Real-time mode

0xA0 - Setup RTmode

0xA1 - RTmode packet - in/out

### **Bootloader operations**

0xF0 - clear application memory

0xF1 - block transfer options

0xF2 - transfer block part

0xF3 - start application

0xF5 - calculate and save CRC

0xF6 - clear user settings

## General

### *Read device data*

- byte 2: 0x00
- byte 3-6: 0
- byte 7: request ID

#### Returned packet:

- byte 2: 0x00
- byte 3: serial MSB
- byte 4: serial LSB
- byte 5: software version (v(1+[4-7]).([0-3]))
- byte 6: revision number
- byte 7: request ID

#### Additional info (newer devices):

- bytes 9-12: string 'PK58' or 'PKEx' (preferred)
- bytes 13-16: 32-bit serial number
- byte 17: firmware version
- byte 18: firmware revision version
- byte 19: HW ID (see table in PoKeys devices chapter)
- byte 20: user ID
- bytes 21-31: build date string
- bytes 32-41: device name string
- byte 42: firmware type ID (0: default firmware)
- bytes 43-44: firmware version of the application (applicable to bootloader)
- bytes 45-57: reserved
- byte 58: product ID offset
- byte 59: configuration lock status
- byte 60: configuration firmware version
- byte 61: configuration firmware revision number
- byte 62: bootloader flag (1 indicates bootloader)

### *Set user ID*

- byte 2: 0x02
- byte 3: ID
- byte 4-6: 0
- byte 7: request ID

#### Returned packet:

- byte 2: 0x02
- byte 3: confirmed ID
- byte 4-6: 0
- byte 7: request ID

### *Read user ID (deprecated, use »Read device data« instead )*

- byte 2: 0x03
- byte 3-6: 0

- byte 7: request ID

Returned packet:

- byte 2: 0x03
- byte 3: userID
- byte 4: device lock status (if 1, device configuration is locked)
- byte 5-6: 0
- byte 7: request ID

### *Read/set device name*

- byte 2: 0x06
- byte 3:
  - 0 for reading device name
  - Bit 0: for writing device name
  - Bit 1: for reading joystick device name
  - Bit 2: read product ID offset
  - Bit 3: set product ID offset
- byte 4: use long device name (1)
- byte 5-6: 0
- byte 7: request ID
- bytes 9-18: device name string
- bytes 19-34: joystick device name string
- byte 35: product ID offset
- bytes 36-55: long device name string
- bytes 56-63: reserved

Returned packet:

- byte 2: 0x06
- byte 3-6: reserved
- byte 7: request ID
- bytes 9-18: device name string
- bytes 19-34: new joystick device name string
- byte 35: product ID offset
- bytes 36-55: long device name string
- bytes 56-63: reserved

### *Read build date (deprecated, use »Read device data« instead )*

- byte 2: 0x04
- byte 3: part (0-2), extended info (10)
- byte 4-6: 0
- byte 7: request ID

Returned packet:

- byte 2: 0x04
- byte 3-6: char 1-4, 5-8, 9-11

- byte 7: request ID

#### Extended info

##### Returned packet:

- byte 2: 0x04
- byte 3: hardware version
- byte 4: hardware revision
- byte 5: hardware architecture
- byte 6: reserved
- byte 7: request ID

#### Configuration saving

- byte 2: 0x50
- byte 3: 0xAA
- byte 4: 0x55
- byte 5-6: 0
- byte 7: request ID

#### Configuration saving and lock

- byte 2: 0x51
- byte 3: 0xAA
- byte 4: 0x55
- byte 5-6: 0
- byte 7: request ID

#### Configuration reset

- byte 2: 0x52
- byte 3: 0xAA
- byte 4: 0x55
- byte 5-6: 0
- byte 7: request ID

#### Get system load status

- byte 2: 0x05
- byte 3-6: 0
- byte 7: request ID

##### Returned packet:

- byte 2: 0x05
- byte 3: system load (in %)

- byte 4-6: reserved
- byte 7: request ID

#### Get tick counter

- byte 2: 0xCF
- byte 3-6: 0
- byte 7: request ID

#### Returned packet:

- byte 2: 0xCF
- byte 3-6: 32-bit tick counter with ms resolution (LSB first)
- byte 7: request ID

#### Read/activate option

- byte 2: 0x8F
- byte 3: 1 for writing, 0 for reading (set to 0xFF to clear all options)
- byte 4-6: 0
- byte 7: request ID
- byte 9-16: option activation code
- bytes 17-63: reserved

#### Returned packet:

- byte 2: 0x8F
- byte 3-6: reserved
- byte 7: request ID
- byte 9: activations OK (bit mapped)
- bytes 10: reserved

#### Enable/disable fast USB interface

- byte 2: 0x07
- byte 3: fast USB interface enable status (set to 10 to read the status only)
- byte 4-6: 0
- byte 7: request ID

#### Returned packet:

- byte 2: 0x07
- byte 3: fast USB interface enable status
- byte 4-6: reserved
- byte 7: request ID

#### Delayed startup configuration

In order to address the issue with selected systems where PoKeys device stops device from booting-up, delayed startup of the PoKeys device can be configured.

Byte	Function
1 (header)	Header (0xBB)
2 (CMD)	0x08
3	Command - 0 for reading the configuration, 1 for writing
4	Startup delay in x100 ms (0 to 25.4 seconds delay available), a value of 0 or 0xFF results in no delay at startup
5-6	reserved
7	Request ID
8 (CRC)	CRC

Delayed startup configuration - Response

Byte	Function
1 (header)	Header (0xAA)
2 (CMD)	0x08
3	Command
4	Startup delay
5-6	Reserved
7	Request ID
8 (CRC)	CRC

### Session settings

These commands are used for managing sessions with PoKeys device

#### 0x0A Session settings

Byte	Function
1 (header)	Header (0xBB)
2 (CMD)	0x0A
3	0x00 – read session data, 0x10 - set session data
4-6	Reserved
7	Request ID
8 (CRC)	CRC
9-18	session data (if byte 3 is set to 0x10)
19-63	Reserved
64 (CRC 2)	CRC

Session settings - Response

Byte	Function
1 (header)	Header (0xAA)
2 (CMD)	0x0A
3-6	Reserved
7	Request ID
8 (CRC)	CRC
9-18	session data
19-63	Reserved
64 (CRC 2)	CRC

## Misc USB device configuration

### *0x0B Misc USB device configuration*

Byte	Function
<b>1 (header)</b>	Header (0xBB)
<b>2 (CMD)</b>	<b>0x0B</b>
<b>3</b>	0x00 – read configuration, 0x10 - set configuration
<b>4-6</b>	Reserved
<b>7</b>	Request ID
<b>8 (CRC)</b>	CRC
<b>9</b>	Interrupt communication interval in ms
<b>10-63</b>	Reserved
<b>64 (CRC 2)</b>	CRC

### Session settings - Response

Byte	Function
<b>1 (header)</b>	Header (0xAA)
<b>2 (CMD)</b>	<b>0x0B</b>
<b>3-6</b>	Reserved
<b>7</b>	Request ID
<b>8 (CRC)</b>	CRC
<b>9</b>	Interrupt communication interval in ms
<b>10-63</b>	Reserved
<b>64 (CRC 2)</b>	CRC

## General pin settings

PoKeys55, PoKeys56, PoKeys57 limitations

- 1. Pin codes used in PoKeys55 device are 0-based, e.g. pin 1 has pin code of 0, pin 55 has pin code of 54.**
- 2. Analog input capable pins 43 to 47 have pin codes of 42 to 46.**
- 3. Analog output capable pin 43 has pin code of 42.**
- 4. PWM (pulse-width modulation) capable pins 17 to 22 have pin codes of 16-21 (PWM module outputs are in reversed order, e.g. pin 17 (pin coded as 16) is connected to PWM6 output – see specifications below).**

## Set input/output settings

- byte 2: 0x10
- byte 3: pin ID (0-54)
- byte 4: pin settings
  - bit 0: special pin function
  - bit 1: digital input
  - bit 2: digital output
  - bit 3: analog input
  - bit 4: analog output
  - bit 5: triggered input
  - bit 6: digital counter input
  - bit 7: invert state
- byte 5: other / digital counter options (PoKeys56E)
  - bit 0: count rising edges (fast counter)
  - bit 1: count falling edges (fast counter)
  - bit 2: disable 10k pull-up resistor (PoPLC)
  - bit 3: enable external analog conversion (PoPLC)
  - bits 4- 5: analog conversion resolution: 0 = 12-bit, 1 = 14-bit, 2 = 16-bit, 3 = 18-bit (PoPLC)
  - bits 6-7: analog pin mode: 0 = normal analog input, 1 = Pt1000 analog input, 2 = 0-10 V analog input, 3 = 4-20 mA analog input (PoPLC)
- byte 6: reserved
- byte 7: request ID

Returned packet:

- byte 2: 0x10
- byte 3: 0 - OK, 1 – Pin number out of range or configuration locked
- byte 4-6: 0
- byte 7: request ID

## Read input/output settings

- byte 2: 0x15
- byte 3: pin ID (0-54)
- byte 4-6: 0
- byte 7: request ID

Returned packet:

- byte 2: 0x15
- byte 3: pin ID (0-54) (or 0xFF if pin number out of range or configuration locked)
- byte 4: pin settings
  - bit 0: reserved
  - bit 1: digital input
  - bit 2: digital output
  - bit 3: analog input
  - bit 4: analog output
  - bit 5: triggered input
  - bit 6: digital counter input
  - bit 7: invert state
- byte 5: reserved / digital counter options - see packet description 0x10 above
- byte 6: extended pin function
- byte 7: request ID

#### Input/output settings - extended mode

	option 1	option 2
Read all pin functions	0	0
Set all pin functions	1	0
Read all additional settings	0	1
Set all additional settings	0	2

- byte 2: 0xC0
- byte 3: option 1 (see table above)
- byte 4: option 2 (see table above)
- byte 5-6: 0
- byte 7: request ID

if (option 1 > 0)

- byte 9-63: pin settings set (see above for value descriptions)  
if (option 1 == 0 and option 2 == 2)

- byte 9-63: pin digital counter options (if set/read additional settings enabled)

Returned packet:

- byte 2: 0xC0
- byte 3: additional settings
- byte 4-6: reserved
- byte 7: request ID

- byte 9-63: pin settings (option 1 == 0 and option 2 == 0)
- byte 9-63: pin digital counter options (option 1 == 0 and option 2 == 1)

### Additional settings

- byte 2: 0x1E
- byte 3: 0 for configuration read, 1 for write
- byte 4: auto-initialize outputs on device startup
- byte 5: set digital outputs startup values (1)
- byte 6: reserved (0)
- byte 7: request ID

- byte 9-15: digital outputs startup values

Returned packet:

- byte 2: 0x1E
- byte 3: auto-initialize outputs status (1 if enabled)
- byte 4: 1 if digital outputs startup values are provided in bytes 9-15
- byte 5-6: reserved
- byte 7: request ID
  
- bytes 9-15: digital outputs startup values

### Get pin capabilities

Request

Byte	Function
<b>1 (header)</b>	Header (0xBB)
<b>2 (CMD)</b>	<b>0x1F</b>
<b>3</b>	0x00 - select pin range (13 pins per read)
<b>4-6</b>	Reserved
<b>7</b>	Request ID
<b>8 (CRC)</b>	CRC
<b>9-63</b>	Reserved
<b>64 (CRC 2)</b>	CRC

Response

Byte	Function
<b>1 (header)</b>	Header (0xAA)
<b>2 (CMD)</b>	<b>0x1F</b>
<b>3</b>	Reserved
<b>4-6</b>	Reserved
<b>7</b>	Request ID
<b>8 (CRC)</b>	CRC
<b>9-62</b>	Pin capabilities (bit-masked) - up to 13 pins per range
<b>63</b>	Reserved
<b>64 (CRC 2)</b>	CRC

Pin basic and extended capabilities bit masks

```
typedef enum
{
```

```

        PK_PinCap_digitalInput      = 2,           // Digital input
        PK_PinCap_digitalOutput     = 4,           // Digital output
        PK_PinCap_analogInput       = 8,           // Analog input (only on selected pins)
        PK_PinCap_analogOutput      = 16,          // Analog output (only on selected pins)
        PK_PinCap_triggeredInput     = 32,          // Triggered input
        PK_PinCap_digitalCounter    = 64,          // Digital counter (only on selected pins)
    } ePinCapabilities;

    typedef enum
    {
        PK_PinExtCap_1wire           = (1<<8),
        PK_PinExtCap_Pt1000          = (1<<9),
        PK_PinExtCap_0_10V           = (1<<10),
        PK_PinExtCap_4_20mA          = (1<<11),
        PK_PinExtCap_FastEnc         = (1<<12),
        PK_PinExtCap_PWM             = (1<<13)
    } ePinExtendedCapabilities;

```

### Key association setting (for pins which are set to 1, 2 or 32)

- byte 2: 0x20
- byte 3: pin ID (0-54)
- byte 4: key modifier (Ctrl/Alt/Shift)
  - bit 0: ctrl
  - bit 1: shift
  - bit 2: Alt
  - bit 3: Windows
  - bit 4: reserved
  - bit 5: reserved
  - bit 6: Alt Gr
  - bit 7: reserved
- byte 5: key KeyCode
- byte 6: option
  - bit 0: enable key mapping
  - bit 1: direct key mapping
  - bit 2: key mapped to macro (KeyCode is macro ID)
  - bit 3: key mapped to continous macro (same as above, but macro is refiring if input is still active)
  - bit 4: key repeating (after a delay, the key is being repeatedly fired with a given rate)
  - bit 5:
  - bit 6:
  - bit 7:
- byte 7: request ID

#### Returned packet:

- byte 2: 0x20
- byte 3: 0 - OK, 1 if pin number out of range or configuration locked, 2 if pin not set as digital input
- byte 4-6: 0
- byte 7: request ID

### Reading of key associations

- byte 2: 0x25
- byte 3: pin ID (0-54)

- byte 4-6: 0
- byte 7: request ID

Returned packet:

- byte 2: 0x25
- byte 3: key modifier
- byte 4: key code
- byte 5: option (see command 0x20)
- byte 6: 0
- byte 7: request ID

### Typematic delay setup

- byte 2: 0x21
- byte 3: option
- byte 4-6: 0
- byte 7: request ID

if (option > 0)

- byte 9-63: pin typematic delay set (set in steps of 5 ms – 0 to 1275 ms possible)

Returned packet:

- byte 2: 0x21
- byte 3-6: reserved
- byte 7: request ID

- byte 9-63: pin typematic delay get (see above for value descriptions)

### Key repeat rate setup

- byte 2: 0x22
- byte 3: option
- byte 4-6: 0
- byte 7: request ID

if (option > 0)

- byte 9-63: pin key repeat rate set (repeat period in 5 ms cycles (plus 1 cycle) – set to 9 (9x 5ms + 1x 5ms = 50ms) to get 20 key presses per second, set to 199 to get 1 key press per second)

Returned packet:

- byte 2: 0x22
- byte 3-6: reserved
- byte 7: request ID

- byte 9-63: pin key repeat rate get (see above for value descriptions)

## Key mappings

- byte 2: 0xC1
- byte 3: option
- byte 4-6: 0
- byte 7: request ID

if (option > 0)

- byte 9-63: pin key mapping set (see above 'option' for value descriptions)

Returned packet:

- byte 2: 0xC1
- byte 3-6: reserved
- byte 7: request ID

- byte 9-63: pin key mapping get (see above 'option' for value descriptions)

## Key codes

- byte 2: 0xC2
- byte 3: option
- byte 4-6: 0
- byte 7: request ID

if (option > 0)

- byte 9-63: pin USB key code set

Returned packet:

- byte 2: 0xC2
- byte 3-6: reserved
- byte 7: request ID

- byte 9-63: pin key code get

## Key modifiers

- byte 2: 0xC3
- byte 3: option
- byte 4-6: 0
- byte 7: request ID

if (option > 0)

- byte 9-63: pin key modifiers set (see above for value descriptions)

Returned packet:

- byte 2: 0xC3

- byte 3-6: reserved

- byte 7: request ID

- byte 9-63: pin key modifiers get (see above for value descriptions)

### Triggered input key mappings

- byte 2: 0xD7

- byte 3: option

- byte 4-6: 0

- byte 7: request ID

Option = 1

- byte 9-63: down key codes for each pin

Option = 2

- byte 9-63: down key modifiers for each pin

Option = 3

- byte 9-63: up key codes for each pin

Option = 4

- byte 9-63: up key modifiers for each pin

Option = 11..14

- byte 9-63: reserved

Option = 20

- byte 9: triggered key length write

Option = 21: read triggered key length

Returned packet:

- byte 2: 0xD7

- byte 3-6: reserved

- byte 7: request ID

Option = 11

- byte 9-63: down key codes for each pin

Option = 12

- byte 9-63: down key modifiers for each pin

Option = 13

- byte 9-63: up key codes for each pin

Option = 14

- byte 9-63: up key modifiers for each pin

Option = 21

- byte 9: triggered key length

### *Get/Set Connection signal pin status*

Connection signal pin status can be set for pins 48 to 55. When USB connection with PC is established, pin for which ' Connection signal pin status' is set to 1, will go into high state (if pin is not inverted). After connection with PC is lost and power through USB is still available, pin will go into low state (if pin is not inverted).

To set the value, set option byte to 1. To read the value, set the option byte to 0.

- byte 2: 0x1B
- byte 3: option
- byte 4: bit mapped Connection signal pin status
- byte 5-6: 0
- byte 7: request ID

Returned packet:

- byte 2: 0x1B
- byte 3: reserved
- byte 4: bit mapped Connection signal pin status
- byte 5-6: reserved
- byte 7: request ID

## Encoder settings

PoKeys supports up to 25 'normal' encoders, 3 fast encoders (mapped to encoders 0, 1 and 2).  
An ultra fast encoder input (mapped to index 25) is supported on PoKeys56E.

Encoder settings

- byte 2: 0x11
- byte 3: encoder ID (0-25)
- byte 4: option
  - bit 0: enable encoder
  - bit 1: 4x sampling
  - bit 2: 2x sampling
  - bit 3: reserved
  - bit 4: direct key mapping for direction A
  - bit 5: mapped to macro for direction A
  - bit 6: direct key mapping for direction B
  - bit 7: mapped to macro for direction B
- byte 5: channel A input
- byte 6: channel B input
- byte 7: request ID

Returned packet:

- byte 2: 0x11
- byte 3: 0 - OK, 1 if encoder ID out of range or configuration locked
- byte 4-6: 0
- byte 7: request ID

## Encoder key mapping for direction A

- byte 2: 0x12
- byte 3: encoder ID (0-25)
- byte 4: reserved
- byte 5: key code or macro ID
- byte 6: key modifier
- byte 7: request ID

Returned packet:

- byte 2: 0x12
- byte 3: 0 - OK, 1 if encoder ID out of range or configuration locked
- byte 4-6: 0
- byte 7: request ID

## Encoder key mapping for direction B

- byte 2: 0x13
- byte 3: encoder ID (0-25)
- byte 4: reserved

- byte 5: key code or macro ID
- byte 6: key modifier
- byte 7: request ID

Returned packet:

- byte 2: 0x13
- byte 3: 0 - OK, 1 if encoder ID out of range or configuration locked
- byte 4-6: 0
- byte 7: request ID

### Read encoder settings

- byte 2: 0x16
- byte 3: encoder (0-25)
- byte 4-6: 0
- byte 7: request ID

Returned packet:

- byte 2: 0x16
- byte 3: encoder (0-25)
- byte 4: option
- byte 5: channel A pin
- byte 6: channel B pin
- byte 7: request ID

### Read encoder key mapping for direction A

- byte 2: 0x17
- byte 3: encoder (0-25)
- byte 4-6: 0
- byte 7: request ID

Returned packet:

- byte 2: 0x17
- byte 3: encoder (0-25)
- byte 4: reserved
- byte 5: key code or macro ID
- byte 6: key modifier
- byte 7: request ID

### Read encoder key mapping for direction B

- byte 2: 0x18
- byte 3: encoder (0-25)
- byte 4-6: 0

- byte 7: request ID

Returned packet:

- byte 2: 0x16
- byte 3: encoder (0-25)
- byte 4: reserved
- byte 5: key code or macro ID
- byte 6: key modifier
- byte 7: request ID

### Read encoder RAW value

- byte 2: 0x19
- byte 3: encoder ID
- byte 4-6: 0
- byte 7: request ID

Returned packet:

- byte 2: 0x19
- byte 3: encoder (0-25)
- byte 4: RAW value
- byte 5: reserved
- byte 6: reserved
- byte 7: request ID

### Reset encoder RAW value

- byte 2: 0x1A
- byte 3: encoder ID
- byte 4-6: 0
- byte 7: request ID

Returned packet:

- byte 2: 0x1A
- byte 3: encoder (0-25)
- byte 4: reserved
- byte 5: reserved
- byte 6: reserved
- byte 7: request ID

### Encoder option

- byte 2: 0xC4
- byte 3: option
- byte 4-6: 0

- byte 7: request ID

if (option > 0)

- bytes 9-33: encoder option set (see above for 'option' values)

Returned packet:

- byte 2: 0xC4

- byte 3-6: reserved

- byte 7: request ID

- bytes 9-33: encoder option get (see above for 'option' values)

### Encoder channel A and B pin

- byte 2: 0xC5

- byte 3: option

- byte 4-6: 0

- byte 7: request ID

if (option > 0)

- bytes 9-33: encoder channel A pin set

- bytes 34-58: encoder channel B pin set

Returned packet:

- byte 2: 0xC5

- byte 3-6: reserved

- byte 7: request ID

- bytes 9-33: encoder channel A pin get

- bytes 34-58: encoder channel B pin get

### Encoder channel A key code and modifier

- byte 2: 0xC6

- byte 3: option

- byte 4-6: 0

- byte 7: request ID

if (option > 0)

- bytes 9-33: encoder channel A key codes set

- bytes 34-58: encoder channel A key modifiers set

Returned packet:

- byte 2: 0xC6
- byte 3-6: reserved
- byte 7: request ID
  
- bytes 9-33: encoder channel A key codes get
- bytes 34-58: encoder channel A key modifiers get

### Encoder channel B key code and modifier

- byte 2: 0xC7
- byte 3: option
- byte 4-6: 0
- byte 7: request ID

if (option > 0)

- bytes 9-33: encoder channel B key codes set
- bytes 34-58: encoder channel B key modifiers set

Returned packet:

- byte 2: 0xC7
- byte 3-6: reserved
- byte 7: request ID
  
- bytes 9-33: encoder channel B key codes get
- bytes 34-58: encoder channel B key modifiers get

### Get encoder long RAW values

- byte 2: 0xCD
- byte 3: option
- byte 4-6: 0
- byte 7: request ID
- option byte:
  - 0 – get encoder RAW values for encoders 1-13
  - 1 – get encoder RAW values for encoders 14-26
  - 10 – set encoder RAW values for encoders 1-13
  - 11 – set encoder RAW values for encoders 14-26

If option == 10

- bytes 9-12: encoder 1 RAW value (LSB first)
- bytes 13-16: encoder 2 RAW value (LSB first)
- bytes 17-20: encoder 3 RAW value (LSB first)
- bytes 21-24: encoder 4 RAW value (LSB first)
- bytes 25-28: encoder 5 RAW value (LSB first)

- bytes 29-32: encoder 6 RAW value (LSB first)
- bytes 33-36: encoder 7 RAW value (LSB first)
- bytes 37-40: encoder 8 RAW value (LSB first)
- bytes 41-44: encoder 9 RAW value (LSB first)
- bytes 45-48: encoder 10 RAW value (LSB first)
- bytes 49-52: encoder 11 RAW value (LSB first)
- bytes 53-56: encoder 12 RAW value (LSB first)
- bytes 57-60: encoder 13 RAW value (LSB first)
  
- bytes 61-63: reserved

If option == 11

- bytes 9-12: encoder 14 RAW value (LSB first)
- bytes 13-16: encoder 15 RAW value (LSB first)
- bytes 17-20: encoder 16 RAW value (LSB first)
- bytes 21-24: encoder 17 RAW value (LSB first)
- bytes 25-28: encoder 18 RAW value (LSB first)
- bytes 29-32: encoder 19 RAW value (LSB first)
- bytes 33-36: encoder 20 RAW value (LSB first)
- bytes 37-40: encoder 21 RAW value (LSB first)
- bytes 41-44: encoder 22 RAW value (LSB first)
- bytes 45-48: encoder 23 RAW value (LSB first)
- bytes 49-52: encoder 24 RAW value (LSB first)
- bytes 53-56: encoder 25 RAW value (LSB first)
- bytes 57-60: Ultra fast encoder RAW value (LSB first)
  
- bytes 61-63: reserved

Returned packet:

- byte 2: 0xCD
- byte 3-6: reserved
- byte 7: request ID

If option == 0

- bytes 9-12: encoder 1 RAW value (LSB first)
- bytes 13-16: encoder 2 RAW value (LSB first)
- bytes 17-20: encoder 3 RAW value (LSB first)
- bytes 21-24: encoder 4 RAW value (LSB first)
- bytes 25-28: encoder 5 RAW value (LSB first)
- bytes 29-32: encoder 6 RAW value (LSB first)
- bytes 33-36: encoder 7 RAW value (LSB first)
- bytes 37-40: encoder 8 RAW value (LSB first)
- bytes 41-44: encoder 9 RAW value (LSB first)
- bytes 45-48: encoder 10 RAW value (LSB first)
- bytes 49-52: encoder 11 RAW value (LSB first)

- bytes 53-56: encoder 12 RAW value (LSB first)
- bytes 57-60: encoder 13 RAW value (LSB first)
  
- bytes 61-63: reserved

If option == 1

- bytes 9-12: encoder 14 RAW value (LSB first)
- bytes 13-16: encoder 15 RAW value (LSB first)
- bytes 17-20: encoder 16 RAW value (LSB first)
- bytes 21-24: encoder 17 RAW value (LSB first)
- bytes 25-28: encoder 18 RAW value (LSB first)
- bytes 29-32: encoder 19 RAW value (LSB first)
- bytes 33-36: encoder 20 RAW value (LSB first)
- bytes 37-40: encoder 21 RAW value (LSB first)
- bytes 41-44: encoder 22 RAW value (LSB first)
- bytes 45-48: encoder 23 RAW value (LSB first)
- bytes 49-52: encoder 24 RAW value (LSB first)
- bytes 53-56: encoder 25 RAW value (LSB first)
- bytes 57-60: Ultra fast encoder RAW value (LSB first)
  
- bytes 61-63: reserved

#### Enable/disable fast encoders on pins 1-2, 3-4 / 5-6 and 15-16

There are two different fast encoders configurations. On newer PoKeys56 devices, only second configuration can be selected.

Configuration 1: pins 1-2 as encoder 1, pins 3-4 as encoder 2, pins 15-16 as encoder 3

Configuration 2: pins 1-2 as encoder 1, **pins 5-6 as encoder 2**, pins 15-16 as encoder 3

- byte 2: 0xCE
- byte 3: option

Bit 7	Bit 6	Bit 5	Bit 4	Bit 3	Bit 2	Bit 1	Bit 0
Encoder 3 invert	Encoder 2 invert	Encoder 1 invert	Disable 4x sampling	configuration <sup>1</sup>			

- byte 4: (bit 0): Enable index signal<sup>2</sup>
- bytes 5-6: reserved
- byte 7: request ID

Returned packet:

- byte 2: 0xCD
- byte 3: status

<sup>1</sup> Set to 1 to enable fast encoders with configuration 1, set to 10 to enable configuration 2, set to 2 to read setup

<sup>2</sup> When set to 1, the pins 9, 11 and 27 function as index signal inputs. If a positive front on these pins is detected, the encoder counter is reset accordingly.

- byte 4: enable index signal
- bytes 5-6: reserved
- byte 7: request ID
- bytes 9-63: reserved

### Enable/disable ultra fast encoder

Ultra fast encoder input is supported only on PoKeys56E.

Pins used are:

Pin 8: Phase A input

Pin 12: Phase B input

Pin 13: Index input

- byte 2: 0x1C
- byte 3: enable ultra fast encoder (set to 1 to enable, set to 0 to disable, set to 0xFF to read configuration)
- byte 4: additional options

Bit 7	Bit 6	Bit 5	Bit 4	Bit 3	Bit 2	Bit 1	Bit 0
reserved					Enable 4x sampling	Signal mode	Invert direction

Signal mode: when = 0, A and B function as quadrature encoder inputs. When = 1, A functions as the direction signal and B functions as the clock signal.

Enable 4x sampling: when = 0, only A edges are counted (2X). When = 1, BOTH A and B edges are counted (4X), increasing resolution but decreasing range.

- byte 5-6: 0
- byte 7: request ID
- bytes 9-12: digital filter sampling delay used in ultra fast encoder

Returned packet:

- byte 2: 0x1C
- byte 3: status
- byte 4: additional options as above
- bytes 5-6: reserved
- byte 7: request ID
- bytes 9-12: digital filter sampling delay used in ultra fast encoder
- byte 13: enable encoders status (copy of byte 3)
- byte 14: encoders options (copy of byte 4)
- bytes 15-63: reserved

## Digital counters

### Get digital counters values

- byte 2: 0xD8
  - byte 3: reserved
  - byte 4-6: 0
  - byte 7: request ID
- 
- bytes 9-21: pin IDs for which the value will be returned

#### Returned packet:

- byte 2: 0xD8
  - byte 3-6: reserved
  - byte 7: request ID
- 
- bytes 9-12: counter value 1 (LSB first)
  - bytes 13-16: counter value 2 (LSB first)
  - bytes 17-20: counter value 3 (LSB first)
  - bytes 21-24: counter value 4 (LSB first)
  - bytes 25-28: counter value 5 (LSB first)
  - bytes 29-32: counter value 6 (LSB first)
  - bytes 33-36: counter value 7 (LSB first)
  - bytes 37-40: counter value 8 (LSB first)
  - bytes 41-44: counter value 9 (LSB first)
  - bytes 45-48: counter value 10 (LSB first)
  - bytes 49-52: counter value 11 (LSB first)
  - bytes 53-56: counter value 12 (LSB first)
  - bytes 57-60: counter value 13 (LSB first)
- 
- bytes 61-63: reserved

### Get/Set digital counter direction pins

- byte 2: 0xD9
  - byte 3: 0 for reading, 1 for writing
  - byte 4-6: 0
  - byte 7: request ID
- 
- bytes 9-63: direction pin ID for each counter. If pin ID is set to zero, no direction input pin will be used and counter's value will always increase

### Reset digital counters values

- byte 2: 0x1D
- byte 3-6: 0
- byte 7: request ID

#### Returned packet:

- byte 2: 0x1D

- byte 3-6: 0
- byte 7: request ID

## I/O operations

### Reading of inputs

- byte 2: 0x30
- byte 3: pin ID (0-54)
- byte 4-6: 0
- byte 7: request ID

#### Returned packet:

- byte 2: 0x30
- byte 3: 0 - OK, 1+ error ID
- byte 4: input value
- byte 5-6: 0
- byte 7: request ID

### Block inputs reading

- byte 2: 0x31
- byte 3-6: 0
- byte 7: request ID

#### Returned packet:

- byte 2: 0x31
- byte 3: pins state 1-8
- byte 4: pins state 9-16
- byte 5: pins state 17-24
- byte 6: pins state 25-32
- byte 7: request ID

### Block inputs reading - part 2

- byte 2: 0x32
- byte 3-6: 0
- byte 7: request ID

#### Returned packet:

- byte 2: 0x32
- byte 3: pins state 33-40
- byte 4: pins state 41-48
- byte 5: pins state 49-55
- byte 6: 0
- byte 7: request ID

## Analog inputs

### *Analog inputs reading:*

- byte 2: 0x35
- byte 3: pin ID
- byte 4-6: 0
- byte 7: request ID

#### Returned packet:

- byte 2: 0x35
- byte 3: 0 - OK, 1+ error ID
- byte 4: input value (8-bit)
- byte 5: MSB (2-bit) (4-bit on PoKeys56/PoKeys57 devices)
- byte 6: LSB (8-bit)
- byte 7: request ID

### *Analog inputs block reading - 4x 8bit*

- byte 2: 0x36
- byte 3: pin for input 1
- byte 4: pin for input 2
- byte 5: pin for input 3
- byte 6: pin for input 4
- byte 7: request ID

#### Returned packet:

- byte 2: 0x36
- byte 3: input 1
- byte 4: input 2
- byte 5: input 3
- byte 6: input 4
- byte 7: request ID

### *Analog inputs block reading - 3x 10bit*

- byte 2: 0x37
- byte 3: pin for input 1
- byte 4: pin for input 2
- byte 5: pin for input 3
- byte 6: 0
- byte 7: request ID

#### Returned packet:

- byte 2: 0x37
- byte 3: MSB 1
- byte 4: MSB 2

- byte 5: MSB 3
- byte 6: LSB 1 LSB 2 LSB 3
- byte 7: request ID

### *Analog inputs reading – all analog inputs in one command*

- byte 2: 0x3A
- byte 3: first pin of the series (0 - default)
- byte 4: number of analog input values (0 - default)
- byte 5-6: reserved
- byte 7: request ID

Returned packet:

- byte 2: 0x3A
- byte 3-6: reserved
- byte 7: request ID

- bytes 9-x: analog inputs values – 2 bytes per input (1 byte for MSB, 1 byte for LSB)

By default, first value is analog input value on pin 41 (on PoKeys56E, value of 0 on PoKeys55), 42 (also 0 on PoKeys55) and 43-47.

### *Get analog RC filter value*

PoKeys uses a discrete low-pass filter with the following equation:

$$y(k) = y(k - 1) * \frac{RC}{RC + 1} + u(k) * \frac{1}{RC + 1}$$

- byte 2: 0x38
- byte 3-6: reserved
- byte 7: request ID

Returned packet:

- byte 2: 0x38
- byte 3-6: RC constant (LSB first)
- byte 7: request ID

### *Set analog RC filter value*

- byte 2: 0x39
- byte 3-6: RC constant (LSB first) – 0 turns filtering off
- byte 7: request ID

Returned packet:

- byte 2: 0x39
- byte 3-6: RC constant (LSB first)
- byte 7: request ID

## Outputs setting

*Early design decision led to digital output values to be inverted. Writing a state 0 to an uninverted output pin results in pin outputting 3.3 V and writing a 1 results in 0 V.*

- byte 2: 0x40
- byte 3: pin ID (0-54)
- byte 4: value (0-1)
- byte 5-6: 0
- byte 7: request ID

Returned packet:

- byte 2: 0x40
- byte 3: 0 - OK, 1+ error ID
- byte 4-6: 0
- byte 7: request ID

## Block outputs writing

code 0x42: set block of outputs 1: byte 3-6: output data (1-32)

code 0x43: set block of outputs 2: byte 3-5: output data (33-55)

## Analog outputs settings

- byte 2: 0x41
- byte 3: pin ID (42)
- byte 4: MSB value (0-255)
- byte 5: LSB value (upper 2 bits)
- byte 6: 0
- byte 7: request ID

Returned packet:

- byte 2: 0x41
- byte 3: 0 - OK, 1+ error ID
- byte 4-6: 0
- byte 7: request ID

## Get device status (extended mode - IO, analog, encoders)

- byte 2: 0xCC
- byte 3: option (0 - short packet, 1 - output data is provided)
- byte 4: reserved
- byte 5: reserved
- byte 6: reserved

- byte 7: request ID

if (option > 0)

- bytes 9-12: output data (1-32) - bit-mapped, bit 0 of byte 9 = pin 1, bit 7 of byte 9 = pin 8, bit 0 of byte 10 = pin 9, etc.

- bytes 13-15: output data (33-55) - bit-mapped output statuses continued

- byte 16: analog output MSB - should be set to 0 for non-PoKeys55 devices

- byte 17: analog output LSB - should be set to 0 for non-PoKeys55 devices

- bytes 18-63: reserved (0)

Returned packet:

- byte 2: 0x41

- byte 3: 0 - OK, 1+ error ID

- byte 4-6: 0

- byte 7: request ID

- bytes 9-12: input status (1-32)

- bytes 13-15: input status (33-55)

- bytes 16-25: analog 1-5 (MSB+LSB for each input)

- bytes 26-50: 25x 8-bit encoder RAW values

- bytes 51-58: matrix keyboard status (each byte is bit-mapped to a matrix keyboard row)<sup>3</sup>

- bytes 59-62: ultra fast encoder RAW value

- byte 63: reserved (0)

---

<sup>3</sup> This status only retrieves first part of the matrix keyboard keys (upper 8x8)

## Joystick settings

Joystick feature supports mapping of analog inputs to joystick analog axes and digital inputs to joystick buttons. In the PoKeys57 series, the support for matrix keyboard keys to joystick buttons mapping was included, supporting first 64 keys of the matrix keyboard (8 rows of 8 buttons). The PoKeys pins therefore are referenced as pins 1 to 55, while matrix keyboard keys are referenced as pins 64-127.

### Read joystick configuration

- byte 2: 0x60
- byte 3-6: reserved
- byte 7: request ID

Returned packet:

- byte 2: 0x60
- bytes 3-6: reserved
- byte 7: request ID
- bytes 9-14: joystick axis mapping
- bytes 15-46: joystick buttons mapping
- bytes 47-50: joystick hat buttons mapping

### Set joystick configuration

- byte 2: 0x65
- byte 3-6: reserved
- byte 7: request ID
- bytes 9-14: joystick axis mapping<sup>4</sup>
- bytes 15-46: joystick buttons mapping (**1-based pin codes**, 0 disables the button, if bit 7 is set, this sets down Event pin)
- bytes 47-50: joystick hat buttons mapping (1-based pin codes)

Returned packet:

- byte 2: 0x65
- byte 3: 0 - OK, 1+ error ID
- byte 4-6: 0
- byte 7: request ID

### Get joystick up Event buttons configuration

- byte 2: 0x61
- byte 3-6: reserved
- byte 7: request ID

Returned packet:

---

<sup>4</sup> Set this value to the 1-based pin code (analog inputs have pin codes from 43 to 47), axes have the following order: rotation x, rotation y, x, y, z and throttle

- byte 2: 0x60
- bytes 3-6: reserved
- byte 7: request ID
- bytes 9-14: reserved
- bytes 15-46: joystick buttons mapping for up event

### *Set joystick up Event buttons configuration*

- byte 2: 0x66
- byte 3-6: reserved
- byte 7: request ID
- bytes 9-14: reserved
- bytes 15-46: joystick buttons up Event mapping (**1-based pin codes**, 0 disables the up Event button)

Returned packet:

- byte 2: 0x61
- byte 3: 0 - OK, 1+ error ID
- byte 4-6: 0
- byte 7: request ID

### *Set/Get joystick analog to digital key mapping options*

- byte 2: 0x6A
- byte 3: option
- byte 4-6: reserved
- byte 7: request ID

if (option = 0, 1 or 2)

- bytes 9-63: reserved (0)
- if (option = 10) - setup for a lower part of the values

- bytes 9-14: mapping type
  - bit 0: enable key mapping
  - bit 1: direct key mapping
  - bit 2: key mapped to macro (KeyCode is macro ID)
  - bit 3: key mapped to continuous macro (same as above, but macro is refiring if input is still active)
  - bit 4: key repeating (after a delay, the key is being repeatedly fired with a given rate)
  - bit 5: reserved
  - bit 6: reserved
  - bit 7: reserved
- bytes 15-20: key code (or macro ID if mapped to macro)
- bytes 21-26: key modifier
- bytes 27-32: Typematic delay (set in steps of 5 ms – 0 to 1275 ms possible)
- bytes 33-38: pin key repeat rate set (repeat period in 5 ms cycles (plus 1 cycle) – set to 9 (9x 5ms + 1x 5ms = 50ms) to get 20 key presses per second, set to 199 to get 1 key press per second)
- bytes 39-44: pin max key repeat rate set
- bytes 45-63: reserved

if (option = 11) - setup for a upper part of the values

- bytes 9-14: mapping type
  - bit 0: enable key mapping
  - bit 1: direct key mapping
  - bit 2: key mapped to macro (KeyCode is macro ID)
  - bit 3: key mapped to continous macro (same as above, but macro is refiring if input is still active)
  - bit 4: key repeating (after a delay, the key is being repeatedly fired with a given rate)
  - bit 5: reserved
  - bit 6: reserved
  - bit 7: reserved
- bytes 15-20: key code (or macro ID if mapped to macro)
- bytes 21-26: key modifier
- bytes 27-32: Typematic delay (set in steps of 5 ms – 0 to 1275 ms possible)
- bytes 33-38: pin key repeat rate set (repeat period in 5 ms cycles (plus 1 cycle) – set to 9 (9x 5ms + 1x 5ms = 50ms) to get 20 key presses per second, set to 199 to get 1 key press per second)
- bytes 39-44: pin max key repeat rate set
- bytes 45-63: reserved

if (option = 2) - band margins setup

- bytes 9-14: lowest value
- bytes 15-20: lower band deadband value
- bytes 21-26: upper band deadband value
- bytes 27-32: highest value

Returned packet:

- byte 2: 0x6A
- byte 3-6: reserved
- byte 7: request ID

if (option = 0) - setup for a lower part of the values

- bytes 9-14: mapping type
  - bit 0: enable key mapping
  - bit 1: direct key mapping
  - bit 2: key mapped to macro (KeyCode is macro ID)
  - bit 3: key mapped to continous macro (same as above, but macro is refiring if input is still active)
  - bit 4: key repeating (after a delay, the key is being repeatedly fired with a given rate)
  - bit 5: reserved
  - bit 6: reserved
  - bit 7: reserved
- bytes 15-20: key code (or macro ID if mapped to macro)
- bytes 21-26: key modifier
- bytes 27-32: Typematic delay (set in steps of 5 ms – 0 to 1275 ms possible)
- bytes 33-38: pin key repeat rate set (repeat period in 5 ms cycles (plus 1 cycle) – set to 9 (9x 5ms + 1x 5ms = 50ms) to get 20 key presses per second, set to 199 to get 1 key press per second)
- bytes 39-44: pin max key repeat rate set
- bytes 45-63: reserved

if (option = 1) - setup for a upper part of the values

- bytes 9-14: mapping type
  - bit 0: enable key mapping
  - bit 1: direct key mapping
  - bit 2: key mapped to macro (KeyCode is macro ID)
  - bit 3: key mapped to continous macro (same as above, but macro is refiring if input is still active)
  - bit 4: key repeating (after a delay, the key is being repeatedly fired with a given rate)
  - bit 5: reserved
  - bit 6: reserved
  - bit 7: reserved
- bytes 15-20: key code (or macro ID if mapped to macro)
- bytes 21-26: key modifier
- bytes 27-32: Typematic delay (set in steps of 5 ms – 0 to 1275 ms possible)
- bytes 33-38: pin key repeat rate set (repeat period in 5 ms cycles (plus 1 cycle) – set to 9 (9x 5ms + 1x 5ms = 50ms) to get 20 key presses per second, set to 199 to get 1 key press per second)
- bytes 39-44: pin max key repeat rate set
- bytes 45-63: reserved

if (option = 2) - band margins setup

- bytes 9-14: lowest value
- bytes 15-20: lower band deadband value
- bytes 21-26: upper band deadband value
- bytes 27-32: highest value

## Macros

### Create macro

- byte 2: 0x90
- byte 3: reserved
- byte 4: macro length
- byte 5: reserved
- byte 6: reserved
- byte 7: request ID

#### Returned packet:

- byte 2: 0x90
- byte 3: macro ID
- byte 4: macro length
- byte 5: 0 - OK, 1+ error ID
- byte 6: reserved
- byte 7: request ID

### Modify macro

- byte 2: 0x91
- byte 3: macro ID
- byte 4: new length
- byte 5: reserved
- byte 6: reserved
- byte 7: request ID

#### Returned packet:

- byte 2: 0x91
- byte 3: macro ID
- byte 4: new length
- byte 5: 0 - OK, 1+ error ID
- byte 6: reserved
- byte 7: request ID

### Delete macro

- byte 2: 0x92
- byte 3: macro ID
- byte 4: reserved
- byte 5: reserved

- byte 6: reserved
- byte 7: request ID

Returned packet:

- byte 2: 0x92
- byte 3: macro ID
- byte 4: reserved
- byte 5: 0 - ok, 1+ error ID
- byte 6: reserved
- byte 7: request ID

### Save macros to flash

- byte 2: 0x93
- byte 3: reserved
- byte 4: reserved
- byte 5: reserved
- byte 6: reserved
- byte 7: request ID

Returned packet:

- byte 2: reserved
- byte 3: reserved
- byte 4: reserved
- byte 5: 0 - ok, 1+ error ID
- byte 6: reserved
- byte 7: request ID

### Rename macro

- byte 2: 0x94
- byte 3: macro ID
- byte 4: index [0..3]
- byte 5: char 1
- byte 6: char 2
- byte 7: request ID

Returned packet:

- byte 2: 0x94
- byte 3: macro ID
- byte 4: reserved
- byte 5: 0 - ok, 1+ error ID
- byte 6: reserved
- byte 7: request ID

### Transfer macro

- byte 2: 0x95
- byte 3: macro ID
- byte 4: index
- byte 5: key code
- byte 6: key modifier
- byte 7: request ID

#### Returned packet:

- byte 2: 0x95
- byte 3: macro ID
- byte 4: reserved
- byte 5: 0 - ok, 1+ error ID
- byte 6: reserved
- byte 7: request ID

### Get macro length

- byte 2: 0x96
- byte 3: macro ID
- byte 4: reserved
- byte 5: reserved
- byte 6: reserved
- byte 7: request ID

#### Returned packet:

- byte 2: 0x96
- byte 3: macro ID
- byte 4: macro length
- byte 5: 0 - ok, 1+ error ID
- byte 6: reserved
- byte 7: request ID

### Get macro name

- byte 2: 0x97
- byte 3: macro ID
- byte 4: index [0..3]
- byte 5: reserved
- byte 6: reserved
- byte 7: request ID

#### Returned packet:

- byte 2: 0x97
- byte 3: macro ID
- byte 4: index
- byte 5: char 1
- byte 6: char 2
- byte 7: request ID

### Get macro keys

- byte 2: 0x98
- byte 3: macro ID
- byte 4: index [0..255]
- byte 5: reserved
- byte 6: reserved
- byte 7: request ID

#### Returned packet:

- byte 2: 0x98
- byte 3: macro ID
- byte 4: index [0..255]
- byte 5: key code
- byte 6: key modifier
- byte 7: request ID

### Get free space

- byte 2: 0x99
- byte 3: reserved
- byte 4: reserved
- byte 5: reserved
- byte 6: reserved
- byte 7: request ID

#### Returned packet:

- byte 2: 0x99
- byte 3: free space MSB
- byte 4: free space LSB
- byte 5: reserved
- byte 6: reserved
- byte 7: request ID

### Get active macros

- byte 2: 0x9A
- byte 3: page [0..1]
- byte 4: reserved
- byte 5: reserved
- byte 6: reserved
- byte 7: request ID

#### Returned packet:

- byte 2: 0x9A
- byte 3: bit masked macro enabled MSB
- byte 4: bit masked macro enabled
- byte 5: bit masked macro enabled
- byte 6: bit masked macro enabled LSB
- byte 7: request ID

### Set/Get macro name and length

- byte 2: 0xC8
- byte 3: option
- byte 4: macro ID
- byte 5-6: 0
- byte 7: request ID

if (option > 0)

- bytes 9-15: new macro name

#### Returned packet:

- byte 2: 0xC8
- byte 3-6: reserved
- byte 7: request ID
  
- bytes 9-15: macro name
- byte 16: macro length

### Set/Get macro keys

- byte 2: 0xC9
- byte 3: option
- byte 4: macro ID
- byte 5: page (25 keys per page)
- byte 6: length
- byte 7: request ID

if (option > 0)

- bytes 9-58: key+modifier pairs
- bytes 59-63: reserved (0)

Returned packet:

- byte 2: 0xC9
- byte 3-6: reserved
- byte 7: request ID
  
- bytes 9-58: key+modifier pairs
- bytes 59-63: reserved (0)

## Matrix keyboard

### Get/Set matrix keyboard configuration

- byte 2: 0xCA
- byte 3: option
- byte 4: keyboard ID
- byte 5: reserved
- byte 6: reserved
- byte 7: request ID

If option == 1<sup>5</sup>

- byte 9: new configuration
  - bit 0: enable matrix keyboard
  - bit 1-7: reserved
- byte 10: size of matrix keyboard<sup>6</sup>
  - bit 0-3: height-1
  - bit 4-7: width-1
- bytes 11-18: row pins<sup>7</sup>
- bytes 19-26: column pins
- bytes 27-42: bit mapped direct/macro (1 for macro), 27.0 for key 0
- bytes 43-50: row pins (if height set to 8 or greater)
- byte 51: pin alternate function enable – pinID (must be input)+1 (value read only if option == 1)
- bytes 52-63: reserved

If option == 2...9<sup>8</sup>

- bytes 9-24: key codes (keys (option-2)\*16 – (option-1)\*16-1)
- bytes 25-40: key modifiers
- bytes 41-42: triggered mode (bit mapped for above keys) – ignored if alternate function is enabled
- bytes 43-63: reserved

If option == 22...29<sup>9</sup>

- bytes 9-24: key codes (keys (option-2)\*16 – (option-1)\*16-1) for up key event (if triggering enabled)
- bytes 25-40: key modifiers for above keys
- bytes 41-63: reserved

### Returned packet:

- byte 2: 0xCA
- byte 3: keyboard ID
- byte 4-6: reserved

---

<sup>5</sup> Use option 1 to setup of the matrix keyboard

<sup>6</sup> This size defines the size of the matrix keyboard in use. For example, if width is set to 4, only columns A-D are used and thus only first four column pins are checked, others are ignored.

<sup>7</sup> Set pin codes appropriately (pins codes are 0-based, so pin 1 has the pin code 0). If width is set to 4, only first four pin codes are read. For unused pins use any value, 0 or 255 is recommended.

<sup>8</sup> Use options 2-5 to setup key codes mapping of the pins. First row of matrix keyboard has keys with indexes from 0 to 7, second row from 8 to 15... Even if matrix keyboard is setup as having only four columns, first row still has keys with indexes 0 to 3, second row from 8 to 11... (values of keys 4-7, 12-15 are not refreshed). Option 2 sets key codes for keys 0-15, Option 3 for keys 16-31...

<sup>9</sup> Use options 2-5 to setup key codes mapping of the pins. First row of matrix keyboard has keys with indexes from 0 to 7, second row from 8 to 15... Even if matrix keyboard is setup as having only four columns, first row still has keys with indexes 0 to 3, second row from 8 to 11... (values of keys 4-7, 12-15 are not refreshed). Option 2 sets key codes for keys 0-15, Option 3 for keys 16-31...

- byte 7: request ID

If option < 12<sup>10</sup>

- byte 9: new configuration
  - bit 0: enable matrix keyboard
  - bit 1-7: reserved
- byte 10: size of matrix keyboard
  - bit 0-3: height-1
  - bit 4-7: width-1
- bytes 11-18: row pins
- bytes 19-26: column pins
- bytes 27-42: bit mapped direct/macro (1 for macro), 27.0 for key 0
- bytes 43-50: row pins (if height set to 8 or greater)
- byte 51: pin alternate function enable – pinID (must be input)+1 (value read only if option == 1)
- bytes 52-63: reserved

If option == 12..19<sup>11</sup>

- bytes 9-24: key codes (keys (option-12)\*16 – (option-11)\*16-1)
- bytes 25-40: key modifiers
- bytes 41-42: triggered mode
- bytes 43-63: reserved

If option == 32..39<sup>12</sup>

- bytes 9-24: key codes (keys (option-12)\*16 – (option-11)\*16-1) for up key event
- bytes 25-40: key modifiers
- bytes 41-63: reserved

If option == 20

- bytes 9-24: matrix keyboard status (whole 16x8 matrix keyboard)

## PWM channels

### Get/set PWM configuration

- byte 2: 0xCB
- byte 3: option
- byte 4: option 2 – set to 1 to update only PWM duty values, else set to 0
- byte 5: reserved
- byte 6: reserved
- byte 7: request ID

If option > 0

- byte 9: bit-mapped PWM enabled

---

<sup>10</sup> Use option less than 12 to retrieve the configuration of the matrix keyboard. If option is used, that is not previously defined for setup of matrix keyboard, settings are only read, none are set.

<sup>11</sup> Retrieve key codes for keys. Look above for description for options 2-5. This options do not change the setup of matrix keyboard.

<sup>12</sup> Retrieve key codes for keys. Look above for description for options 2-5. This options do not change the setup of matrix keyboard.

- bit 0: enable PWM1 (pin 22)
- bit 1: enable PWM2 (pin 21)
- bit 2: enable PWM3 (pin 20)
- bit 3: enable PWM4 (pin 19)
- bit 4: enable PWM5 (pin 18)
- bit 5: enable PWM6 (pin 17)
- bytes 10-13: PWM1 value (LSB first)
- bytes 14-17: PWM2 value
- bytes 18-21: PWM3 value
- bytes 22-25: PWM4 value
- bytes 26-29: PWM5 value
- bytes 30-33: PWM6 value
  
- bytes 34-37: PWM period
- bytes 38-63: reserved

**Returned packet:**

- byte 2: 0xCB
- bytes 3-6: reserved
- byte 7: request ID
  
- byte 9: bit-mapped PWM enabled
- bit 0: enable PWM1 (pin 22)
- bit 1: enable PWM2 (pin 21)
- bit 2: enable PWM3 (pin 20)
- bit 3: enable PWM4 (pin 19)
- bit 4: enable PWM5 (pin 18)
- bit 5: enable PWM6 (pin 17)
- bytes 10-13: PWM1 value
- bytes 14-17: PWM2 value
- bytes 18-21: PWM3 value
- bytes 22-25: PWM4 value
- bytes 26-29: PWM5 value
- bytes 30-33: PWM6 value
  
- bytes 34-37: PWM period
- bytes 38-63: reserved

**LCD displays**

Primary pin assignment	Secondary pin assignment
- DB4 = Pin 26	- DB4 = Pin 34
- DB5 = Pin 25	- DB5 = Pin 33
- DB6 = Pin 24	- DB6 = Pin 32
- DB7 = Pin 23	- DB7 = Pin 31
- E = Pin 30	- E = Pin 30
- RW = Pin 28	- RW = Pin 28
- RS = Pin 29	- RS = Pin 29

## Set LCD configuration

- byte 2: 0xD0
- byte 3: 0 for writing, 1 for reading only
- byte 4: LCD enabled
  - 0 – LCD disabled
  - 1 – LCD enabled on primary pins (23-26)
  - 2 – LCD enabled on secondary pins (31-34)
- byte 5: number of rows
- byte 6: number of columns
- byte 7: request ID

### Returned packet:

- byte 2: 0xD0
- byte 3: reserved
- byte 4: LCD enabled
- byte 5: number of rows
- byte 6: number of columns
- byte 7: request ID

## LCD operation

- byte 2: 0xD1
- byte 3: LCD operation
- byte 4-6: reserved
- byte 7: request ID

### LCD operations

- Init LCD – operation code 0
  - No additional parameters
- Clear LCD – operation code 0x10
  - No additional parameters
- Move cursor – operation code 0x20
  - Byte 4: x position (column) (x=1 for the first column)
  - Byte 5: y position (row) (y=1 for the first row)
- Print to LCD – operation code 0x30
  - Bytes 9-29: string to be printed on screen (up to 20 characters, \0 terminated)
- Put character to LCD – operation code 0x31
  - Byte 9: character code
  
- Define custom character – operation code 0x40
  - Byte 9: character code
  - Bytes 10-17: character data
- Entry mode set – operation code 0x50
  - Byte 9: cursor move direction (1 – increment, 0 – decrement)
  - Byte 10: display shift on/off
- Display on/off control – operation code 0x60
  - Byte 9: display on/off
  - Byte 10: cursor on/off
  - Byte 11: cursor blinking on/off
- Set LCD mode – operation code 0x80
  - Byte 4: 0 - Direct (default) mode / 1 - Buffered mode
- Buffered mode write – operation code 0x85

- Byte 4: row
- Bytes 9-33: 24 bytes

**Returned packet:**

- byte 2: 0xD1
- byte 3-6: reserved
- byte 7: request ID

### Matrix LED display operations

Matrix LED display pins are fixed due to hardware design. On PoKeys55 device (pin numbers for PoKeys prototype design are given in parenthesis), pins used are

Display 1:

- Pin **9** (10): serial data
- Pin **10** (11): output register clock
- Pin **11** (12): serial clock

Display 2:

- Pin **23** (23): serial data
- Pin **24** (24): output register clock
- Pin **25** (25): serial clock

### Get/set Matrix LED display configuration

- byte 2: 0xD5
- byte 3: option<sup>13</sup>
- byte 4: matrix LED enabled
  - bit 0: enable display 1
  - bit 1: enable display 2
- byte 5: display 1 size
  - bits 0-3: number of rows (1...8)
  - bits 4-7: number of columns (1...8)
- byte 6: display 2 size
  - bits 0-3: number of rows (1...8)
  - bits 4-7: number of columns (1...8)
- byte 7: request ID

#### Returned packet:

- byte 2: 0xD5
- byte 3: reserved
- byte 4: matrix LED enabled
- byte 5: display 1 size
- byte 6: display 2 size
- byte 7: request ID

### Update matrix LED display

- byte 2: 0xD6
- byte 3: action
  - 1 - update whole display 1 (ignoring row and column bytes)
  - 5 - set pixel at row,column on display 1 (ignoring row data bytes 9-16)
  - 6 - clear pixel at row,column on display 1
  - 11 - update whole display 2 (ignoring row and column bytes)
  - 15 - set pixel at row,column on display 2 (ignoring row data bytes 9-16)
  - 16 - clear pixel at row,column on display 2

---

<sup>13</sup> To set the configuration, set option byte to 0, else only reading operation will commence

- byte 4: row<sup>14</sup>
  - byte 5: column<sup>15</sup>
  - byte 6: reserved
  - byte 7: request ID
- 
- byte 9-16: row data (LSB bit of each byte is assigned to a pixel on left of a row)
  - bytes 17-63: reserved

**Returned packet:**

- byte 2: 0xD6
- bytes 3-6: reserved
- byte 7: request ID

### PoExtBus functionality

PoExtBus enables to extend number of PoKeys device outputs for 80. This is accomplished using up to 10 daisy-chained 8-bit shift registers with latches. Bit 0 of byte 0 is sent first, followed by bits 1-7 then bits 0-7 of byte 1... If shorter chains of shift registers are used, use only the highest bytes (in case only one shift register is used, only use byte 9 to send data).

Connector option 0 (only on PoKeys56E and PoKeys56U): PoExtBus has a dedicated connector on PoKeys56 board. This option enables this connector.

Pins used are (PoKeys55 and PoKeys56) – connector option 1

- Pin code **34** (35): serial clock
- Pin code **35** (36): serial data
- Pin code **36** (37): output register clock

### Set PoExtBus settings

- byte 2: 0xDA
- byte 3: PoExtBus option (set to 1 to enable PoExtBus, set to 0 to disable and set to 2 to read the state)
- byte 4: connector selection (only on PoKeys56E and PoKeys56U)
- bytes 5-6: reserved
- byte 7: request ID
- bytes 9-18: data bytes

**Returned packet:**

- byte 2: 0xDA
  - byte 3: PoExtBus status
  - byte 4: Connector selection
  - byte 5-6: reserved
  - byte 7: request ID
- 
- bytes 9-18: data bytes

---

<sup>14</sup> Row and column indexes are 0-based.

<sup>15</sup> Row and column indexes are 0-based.



## I<sup>2</sup>C communication bus

PoKeys56E devices support communication with I<sup>2</sup>C slave devices, connected to the PoExtBus connector. Both I<sup>2</sup>C and PoExtBus use the same connector and those two protocols share the connector on a priority-based rule. By default, both PoExtBus and I<sup>2</sup>C are enabled, but PoExtBus update has higher priority than I<sup>2</sup>C. When PoExtBus outputs must be refreshed, I<sup>2</sup>C is temporarily disabled, PoExtBus is refreshed, then I<sup>2</sup>C is enabled again (all this is transparently done by PoKeys device itself). Up to 30 bytes can be transferred in one I<sup>2</sup>C transaction.

Marking the pin closer to the bottom of the board (the opposite side of either Ethernet or USB connector) as pin 1, the I<sup>2</sup>C devices should be connected as follows:

Pin 1	Power supply 3.3V
Pin 2	Ground
Pin 3	Serial data
Pin 4	
Pin 5	Serial clock

## I<sup>2</sup>C settings and communication

- byte 2: 0xDB
- byte 3: I<sup>2</sup>C operation
- byte 4-6: reserved (defined below)
- byte 7: request ID

### I<sup>2</sup>C operations

- ~~0x00 - Deactivate I<sup>2</sup>C~~ - **deprecated command, I<sup>2</sup>C bus is always activated**
  - No additional parameters
- ~~0x01 - Activate I<sup>2</sup>C~~ - **deprecated command, I<sup>2</sup>C bus is always activated**
  - No additional parameters
- ~~0x02 - Get activation status~~ - **deprecated command, I<sup>2</sup>C bus is always activated**
  - No additional parameters (returns successful if I2C turned on)
- 0x10 - Write to I<sup>2</sup>C - start
  - Byte 4: address of the device
  - Byte 5: length of data packet
  - Byte 6: number of bytes to read after write
  - Bytes 9-40: data bytes
- 0x11 - Write to I<sup>2</sup>C - get result
- 0x20 - Read from I<sup>2</sup>C - start
  - Byte 4: address of the device
  - Byte 5: length of data packet
- 0x21 - Read from I<sup>2</sup>C - get result
- 0x30 - Scan I<sup>2</sup>C - start
- 0x31 - Scan I<sup>2</sup>C - get result

### Returned packet:

- byte 2: 0xDB
- byte 3: I<sup>2</sup>C operation
- byte 4: I<sup>2</sup>C operation result (1 if successful, 0 unsuccessful, 0x10 - operation still executing)
- byte 5-6: reserved
- byte 7: request ID

### I<sup>2</sup>C operations

- 0x21 - Read from I<sup>2</sup>C - get result
  - Byte 9: operation result (copied from byte 4)
  - Byte 10: data length

- Bytes 11-42: data bytes
- 0x31 - Scan I<sup>2</sup>C – get result
  - Byte 9: operation result (copied from byte 4)
  - Bytes 10-25: bit encoded result (if bit 0 of byte 10 is set, I2C device with the address of 0x00 was detected)

## PoNET – »PoI2C« commands

### *PoNET settings and communication*

- byte 2: 0xDD
- byte 3: PoI2C operation
- byte 4-6: reserved (defined below)
- byte 7: request ID

#### PoNET operations

- 0x00 – Get PoNET status
- 0x10 – Get PoNET module settings (i2c address, type, size, options)
  - Byte 4: Module ID
- 0x11 – Get PoNET firmware version
  - Byte 4: Module ID
- 0x15 – Set PoNET module settings (mapping options)
  - Byte 4: Module ID
  - Byte 5: Mapping options
- 0x20 – Clear PoNET module settings
  - Byte 4: Module ID
- 0x21 – Reinitialize PoNET
- 0x25 – Reinitialize PoNET and clear settings
- 0x30 – New device discovery
  - Byte 4: Activate (0x10) / deactivate (0x20) / get status (0x30)
- 0x40 – Check for devices
  - Byte 4: Start (0x10) / Get status (0x30)
- 0x50 – Get PoNET module data
  - Byte 4: Start (0x10) / Get data and status (0x30)
  - Byte 5: Module ID
- 0x55 – Set PoNET module data
  - Byte 4: Module ID
  - Bytes 9-24: data
- 0x60 – Get Light sensor value
  - Byte 4: Start (0x10) / Get data and status (0x30)
  - Byte 5: Module ID
- 0x70 – Set PWM value
  - Byte 4: Module ID
  - Byte 5: PWM value
- 0xF0 – Start bootloader
  - Byte 4: Execute (0x10) / get status (0x30)
  - Byte 5: Module ID
- 0xF1 – Start programming
  - Byte 4: Execute (0x10) / get status (0x30)
- 0xF2 – Transfer firmware part
  - Byte 4: Execute (0x10) / get status (0x30)
  - Bytes 9-16: Firmware data (8 bytes)
- 0xF3 – Finish firmware transfer and restart
- 0xF4 – Exit bootloader mode
  - Byte 4: Execute (0x10) / get status (0x30)
- 0xF5 – Activate bootloader
  - Byte 4: Execute (0x10) / get status (0x30)

#### **Returned packet:**

- byte 2: 0xDD
- byte 3: PoNET operation
- byte 4: PoNET operation result (1 if successful, 0 unsuccessful, 0x10 – operation still executing)
- byte 5-6: reserved

- byte 7: request ID

PoNET operations:

- 0x00 – Get PoNET status
  - Byte 9: PoNET state
    - PoNET\_inactive = 0,
    - PoNET\_initializing = 1,
    - PoNET\_scanningI2C = 2,
    - PoNET\_initialized = 10,
  
    - PoNET\_newDevice = 20,
    - PoNET\_newDeviceCheck = 21,
  
    - PoNET\_retrievingConfigurationCommand = 30,
    - PoNET\_retrievingConfigurationResponse = 35,
  
    - PoNET\_readingStatusCommand = 50,
    - PoNET\_readingStatusResponse = 55,
  
    - PoNET\_writingData = 60,
  
    - PoNET\_readingLightCommand = 70,
    - PoNET\_readingLightResponse = 71,
  
    - PoNET\_settingPWMcommand = 80,
  
    - PoNET\_bootloader = 100,
  
    - PoNET\_PoExtBusScanning = 200,
  
    - PoNET\_error = 255
- 0x10 – Get PoNET module settings (i2c address, type, size, options)
  - Byte 9: assigned i2c address
  - Byte 10: module type
    - 0x10 = PoEBkb v1
  - Byte 11: module size
  - Byte 12: module options
    - bit 0 - has inputs
    - bit 1 - has outputs
    - bit 2 - x-y rotated
    - bit 3 - light sensor present
    - bit 4 - device mapped to PoKeys peripheral
    - bit 5 - configuration retrieved
    - bit 6 - device configured
    - bit 7 - device present
- 0x11 – Get PoNET firmware version
  - Byte 9: firmware version
- 0x30 – New device discovery
  - Byte 9 (get status): 1 if newly added device was configured
- 0x40 – Check for devices
  - Byte 9 (get status): 1 if unconfigured device detected
- 0x50 – Get PoNET module data – get data ans status (0x30)
  - Byte 9: Status (0xFF if still reading)
  - Bytes 10-25: PoNET module data
- 0x60 – Get Light sensor value - get data ans status (0x30)

- Byte 9: status (0xFF if still reading)
- Byte 10: sensor value
- 0xF0 – Start bootloader
  - Byte 9: bootloader started flag
- 0xF1 – Start programming
  - Byte 9: programming started flag
- 0xF2 – Transfer firmware part
  - Byte 9: transfer complete
- 0xF5 – Activate bootloader
  - Byte 9: 1 if bootloader detected

### kbd48CNC specifics:

Left the upper left key be designated with coordinates (0,0), x-axis going to the right of the keyboard and the y-axis going to the bottom. Then the key statuses can be decoded as

```
private Point DecodeButtonPosition(int byteIndex, int bitIndex)
{
    Point t = new Point();

    t.X = (byteIndex ^ 1) * 2;
    if (bitIndex < 4)
    {
        t.X++;
        t.Y = bitIndex;
    }
    else
    {
        t.Y = 7 - bitIndex;
    }

    return t;
}

private void SetLED(int x, int y, bool status)
{
    int byteindex = 1 ^ (int)(x / 2);
    int bitindex = y;

    if ((x % 2) == 0)
    {
        bitindex = 7 - y;
    }

    if (status)
    {
        LEDstatus[byteindex] |= (byte)(1 << bitindex);
    }
    else
    {
        LEDstatus[byteindex] &= (byte)~(1 << bitindex);
    }
}
```

## SPI communication bus

PoKeys56U, PoKeys56E and PoKeys57E devices support communication with SPI slave devices. Chip select pins can be freely selected. SPI configuration is not saved in the device.

SPI pin	PoKeys56U pin ID	PoKeys56E/PoKeys57E pin ID
MOSI	9	23
MISO	10	28
SCK	11	25

## SPI settings and communication

- byte 2: 0xE5
- byte 3: SPI operation
- byte 4-6: reserved (defined below)
- byte 7: request ID

### SPI operations

- 0x00 - Disable SPI (not implemented)
  - No additional parameters
- 0x01 - Enable SPI
  - Byte 4: Prescaler value (2-254, even only)
  - Byte 5: SPI format (bit 0 = CPOL, bit 1 = CPHA)
- 0x10 - Write to SPI - start
  - Byte 4: length of data packet (1 to 16, 1 to 55 with 3.1.46)
  - Byte 5: pin ID to use as CS
  - Bytes 9-63: data bytes
- 0x20 - Read SPI
  - Byte 4: data length

### Returned packet:

- byte 2: 0xE5
- byte 3: SPI operation
- byte 4: SPI operation result (1 if successfull, 0 unsuccessfull, 0x10 – operation still executing)
- byte 5-6: reserved
- byte 7: request ID

### SPI operations

- 0x20 - Read SPI – get result
  - Bytes 9-63: data bytes

## 1-wire communication bus

1-wire protocol uses Pin 55 and needs external 5kΩ pull-up resistor. On PoKeys57 series devices, any pin can be used for 1-wire communication.

### 1-wire settings and communication

- byte 2: 0xDC
- byte 3: 1-wire operation
- byte 4: PoKeys pin (only on PoKeys57)
- byte 5-6: reserved (defined below)
- byte 7: request ID

#### 1-wire operations

- 0x00 - Deactivate 1-wire
  - No additional parameters
- 0x01 - Activate 1-wire
  - No additional parameters
- 0x02 – Get activation status (returns successfull if 1-wire turned on)
- 0x10 – Start Reset, Write and Read process
  - Byte 4: number of bytes to write (up to 16)
  - Byte 5: number of bytes to read (up to 16)
  - Byte 6: pin ID (PoKeys57)
  - Bytes 9-24: data bytes
- 0x11 – Get result of read process
- 0x20 - Start bus scan (PoKeys57)
  - Byte 4: pin ID
- 0x21 - Get bus scan status (PoKeys57)
- 0x22 - Continue bus scan (PoKeys57)
- 0x23 - Stop bus scan (PoKeys57)

#### Returned packet:

- byte 2: 0xDC
- byte 3: 1-wire operation
- byte 4: 1-wire operation result (1 if successfull, 0 unsuccessfull, 0x10 – operation still executing)
- byte 5-6: reserved
- byte 7: request ID

#### 1-wire operations

- 0x11 - Get result of read process
  - Byte 9: operation result (copied from byte 4)
  - Byte 10: data length
  - Bytes 11-26: data bytes
- 0x21 - Get bus scan status
  - Byte 9: operation result (copied from byte 4)
  - Byte 10: scan result (bit 0: scan stage complete, bit 1: all devices scanned)
  - Bytes 11-18: device ROM

## UART communication

### *0xDE/0x10 Setup UART communication*

Request

Byte	Function
<b>1 (header)</b>	Header (0xBB)
<b>2 (CMD)</b>	<b>0xDE</b>
<b>3</b>	0x10 - Setup UART communication
<b>4</b>	Interface (1, 2 or 3)
<b>5</b>	Frame format
<b>6</b>	Reserved
<b>7</b>	Request ID
<b>8 (CRC)</b>	CRC
<b>9-12</b>	Baudrate
<b>13-63</b>	Reserved
<b>64 (CRC 2)</b>	unused

Response

Byte	Function
<b>1 (header)</b>	Header (0xAA)
<b>2 (CMD)</b>	<b>0xDE</b>
<b>3</b>	0x10 - Setup UART communication
<b>4-6</b>	Reserved
<b>7</b>	Request ID
<b>8 (CRC)</b>	CRC
<b>9-63</b>	Reserved
<b>64 (CRC 2)</b>	unused

### *0xDE/0x20 Send data*

Request

Byte	Function
<b>1 (header)</b>	Header (0xBB)
<b>2 (CMD)</b>	<b>0xDE</b>
<b>3</b>	0x20 - Send data
<b>4</b>	Interface (1, 2 or 3)
<b>5</b>	Byte count
<b>6</b>	Reserved
<b>7</b>	Request ID
<b>8 (CRC)</b>	CRC
<b>9-63</b>	Data bytes
<b>64 (CRC 2)</b>	unused

Response

Byte	Function
<b>1 (header)</b>	Header (0xAA)
<b>2 (CMD)</b>	<b>0xDE</b>
<b>3</b>	0x20 - Send data

<b>4</b>	Data bytes queued
<b>5-6</b>	Reserved
<b>7</b>	Request ID
<b>8 (CRC)</b>	CRC
<b>9-63</b>	Reserved
<b>64 (CRC 2)</b>	unused

### *0xDE/0x30 Read data*

Request

Byte	Function
<b>1 (header)</b>	Header (0xBB)
<b>2 (CMD)</b>	<b>0xDE</b>
<b>3</b>	0x30 - Read data
<b>4</b>	Interface (1, 2 or 3)
<b>5-6</b>	Reserved
<b>7</b>	Request ID
<b>8 (CRC)</b>	CRC
<b>9-63</b>	Reserved
<b>64 (CRC 2)</b>	unused

Response

Byte	Function
<b>1 (header)</b>	Header (0xAA)
<b>2 (CMD)</b>	<b>0xDE</b>
<b>3</b>	0x30 - Read data
<b>4</b>	Data bytes available
<b>5-6</b>	Reserved
<b>7</b>	Request ID
<b>8 (CRC)</b>	CRC
<b>9-63</b>	Data bytes
<b>64 (CRC 2)</b>	unused

### Real-Time mode (experimental, not implemented in current release)

Real-Time mode enables application to increase the speed of capturing data from PoKeys device on the account of reliability (similar to the relation between TCP and UDP protocols).

In RTmode, PoKeys device will constantly respond with the packet 0xA1. RTmode is automatically disabled when any other packet (other than 0xA1) is received.

#### RTmode – setup

- byte 2: 0xA0
- byte 3: enable RTmode (set to 1 to enable, set to 0 to disable)
- byte 4: reserved
- byte 5: reserved
- byte 6: reserved
- byte 7: request ID

Returned packet:

- byte 2: 0xA0
- byte 3: 0 - OK, 1+ error ID
- byte 4-6: 0
- byte 7: request ID

#### RTmode – set/get data

- byte 2: 0xA1
- byte 3: option (1 - output data is provided)
- byte 4: reserved
- byte 5: reserved
- byte 6: reserved
- byte 7: request ID

if (option > 0)

- bytes 9-12: output data (1-32) (LSB first)
- bytes 13-15: output data (33-55) (LSB first)
- bytes 16-39: 6x 32-bit PWM outputs duty cycles (MSB first)
- bytes 40-63: reserved (0)

Returned packet:

- byte 2: 0xA1
- byte 3: 0 - OK, 1+ error ID
- byte 4-6: 0
- byte 7: request ID
  
- bytes 9-12: input status (1-32) (LSB first)
- bytes 13-15: input status (33-55) (LSB first)
- bytes 16-29: 12-bit analog inputs 1-7 (MSB+LSB for each input)
- bytes 30-45: 4x 32-bit fast encoder RAW values (MSB first)

- bytes 46-49: tick counter (MSB first)
- bytes 50-63: reserved (0)

## Network settings

PoKeys56E device is a network device. It uses a combination of TCP/IP and UDP/IP to communicate. It supports either fixed IP or IP assigned by DHCP server.

Due to exposed nature of the network device, a simple authentication mechanism was implemented. When the device is locked, user must enter the password (or an application instead of user directly) at the beginning of each new connection.

First, the 'Get security setting status' must be called, which returns the current level of security (0 is fully unlocked, 0xFF is fully locked) and the 32-bytes of hash seed. When user enters the password, the ASCII values of the password is XOR-ed with the hash seed to produce 32-bytes of data that is fed into the SHA-1 algorithm to calculate 20-bytes of SHA-1 hash value. This value is then sent as an authentication password in the 'Autorize user' command. This approach provides some degree of protection against unauthorized use of the device.

### Get/set network configuration

- byte 2: 0xE0
- byte 3: option<sup>16</sup>
- bytes 4-6: reserved
- byte 7: request ID
- If (option == 10)<sup>17</sup>
  - byte 9: IP setup – 0 for fixed IP, 1 for DHCP server assigned one
  - bytes 10-13: fixed IP
  - bytes 14-17: reserved
  - bytes 18-19: TCP connection timeout (default **30** x100 ms = 3s)
  - bytes 20-23: Gateway IP
  - bytes 24-27: Subnet mask
  - byte 28: 1 if gateway and subnet are also set
  - byte 29: additional options - bits 7:4 are 0xA, lower are the following:
    - bit 3: reserved
    - bit 2: disable IP configuration via UDP broadcast
    - bit 1: disable automatic device IP configuration during discovery
    - bit 0: disable automatic device discovery mechanism

### Returned packet:

- byte 2: 0xE0
- byte 3-6: reserved
- byte 7: request ID
- byte 9: IP setup
- bytes 10-13: fixed IP
- bytes 14-17: current IP (if assigned by DHCP server)
- bytes 18-19: TCP connection timeout
- bytes 20-23: Gateway IP
- bytes 24-27: Subnet mask
- byte 28: additional options as described in the packet above

---

<sup>16</sup> To set the configuration, set option byte to 10, else only reading operation will commence

<sup>17</sup> This command also saves the configuration

### Get security setting status

- byte 2: 0xE1
- bytes 3-6: reserved
- byte 7: request ID

#### **Returned packet:**

- byte 2: 0xE1
- byte 3-6: reserved
- byte 7: request ID
- byte 9: current security level
- bytes 10-41: seed for calculating the password hash

### Authorise user

- byte 2: 0xE2
- byte 3: security level to unlock to (0 means full unlock)
- bytes 4-6: reserved
- byte 7: request ID
- byte 9-28: password hash code

#### **Returned packet:**

- byte 2: 0xE2
- byte 3-6: reserved
- byte 7: request ID
- byte 9: unlock status (0 means error, 0xAA means succeeded)

### Set user password

- byte 2: 0xE3
- byte 3: Default security setting
- bytes 4-6: reserved
- byte 7: request ID
- byte 9-40: password in plain text

#### **Returned packet:**

- byte 2: 0xE3
- byte 3-6: reserved
- byte 7: request ID

## Modbus settings

For Modbus in PoKeys56E these options can be specified:

- **Modbus port number:** default port number for Modbus TCP protocol is 502. User can however change the port number to other values
- **Modbus connection timeout:** When the connection is not in use for more than (Timeout x 100ms), the connection is dropped and new connections can be established
- **Modbus read/write access settings:** User can define, which peripherals are accessible through Modbus protocol (access settings are bit encoded):
 

```
#define access_IO (1<<0)
#define access_analogIn (1<<1)
#define access_PWMOut (1<<2)
#define access_MatrixKB (1<<3)
#define access_I2CMatrixKB (1<<4)
#define access_I2CMatrixKBLED (1<<5)
#define access_LEDMatrix (1<<6)
#define access_PoExtBus (1<<7)
#define access_Encoders (1<<8)
#define access_Counters (1<<9)
#define access_LCD (1<<10)
#define access_SensorList (1<<11)
#define access_PoL (1<<12)
#define access_PoLcore (1<<13)
```

Modbus registers:

Address (0-based)	Access (R – Read, W – Write)	Description
10-16	R	Analog inputs
20-45	RW	Encoder counter values (lower 16-bit)
100-154	RW	Digital counter values
200-213	RW	PWM
200,201		PWM period (MSB first)
202,203		PWM duty1 (MSB first) – pin 22
...		
212,213		PWM duty6 (MSB first) – pin 17
300-304	RW	PoExtBus
400-453	R	Sensors (32-bit values, LSB first)
500-579	RW	LCD buffer
590	W	LCD configuration (0=disabled, 1=primary or 2=secondary) - writing to this register will re-init and clear the LCD
591	W	Number of rows (lower byte) and number of columns (upper byte) of the LCD module
592	W	Not used
593	W	Clear LCD (both bytes = 0xAA)
600	R	Tick counter (lower 16-bit)
610	RW	RTC seconds
611	RW	RTC minutes
612	RW	RTC hours
613	RW	RTC day
614	RW	RTC day of week
615	RW	RTC month
616	RW	RTC year

<b>620</b>	RW	PoLL core state Set to: 0 - stop core 1 - reset core 10 - set core into run mode
<b>700-751</b>	R[W]	Digital encoder values (32-bit values, LSB first) - any write to these registers causes the reset of the encoder value to 0
<b>800-909</b>	RW	Digital counter values (32-bit values, LSB first)
<b>1000-1127</b>	RW	PoLL shared data slots (32-bit values/2 registers per slot, LSB first!)

#### Get/set modbus settings

- byte 2: 0xE4
- byte 3: option<sup>18</sup>
- bytes 4-6: reserved
- byte 7: request ID
- If (option == 10)
  - bytes 9-10: Modbus port number (LSB first)
  - bytes 11-12: Modbus connection timeout (in x100 ms)
  - bytes 13-16: Modbus read access settings
  - bytes 17-20: Modbus write access settings

#### Returned packet:

- byte 2: 0xE4
- byte 3-6: reserved
- byte 7: request ID
- bytes 9-10: Modbus port number
- bytes 11-12: Modbus connection timeout (in x100 ms)
- bytes 13-16: Modbus read access settings
- bytes 17-20: Modbus write access settings

---

<sup>18</sup> To set the configuration, set option byte to 10, else only reading operation will commence

## Web interface

PoKeys56E acts like a HTTP server and serves simple web pages that reflect certain information on the state of the device. The web interface has the following options:

- Web interface can be disabled – PoKeys56E won't react to http requests on port 80
- Anonymous access to dashboard and IO status can be enabled
- Outputs can be allowed to be toggled via web interface

For security measures, PoKeys56E supports one administrator account and three additional user accounts.

### Setup web interface settings

- byte 2: 0x73
- byte 3: if setting the configuration, set bit 7 to 1
- byte 4-6: reserved
- byte 7: request ID
- bytes 9: disable web interface (disabled if 1)
- bytes 10: allow anonymous access to dashboard and IO status page (enabled if 1)
- bytes 11: allow anonymous access to dashboard and IO status page (enabled if 1)

### Returned packet:

- byte 2: 0x73
- byte 3-6: reserved
- byte 7: request ID
- bytes 9: disable web interface (disabled if 1)
- bytes 10: allow anonymous access to dashboard and IO status page (enabled if 1)
- bytes 11: allow anonymous access to dashboard and IO status page (enabled if 1)

## User accounts

Four user accounts exist. First is for the administrator and its username can not be changed. It defaults to Admin.

### Setup user account

- byte 2: 0x72
- byte 3: user account ID (0 to 3, set bit 7 to set the configuration)
- byte 4-6: reserved
- byte 7: request ID
- bytes 9-16: user name (8 characters)
- bytes 17-24: password (8 characters)

### Returned packet:

- byte 2: 0x72
- byte 3-6: reserved
- byte 7: request ID
- bytes 9-16: user name (8 characters)
- bytes 17-24: password (8 characters)

## Dashboard items

PoKeys56E supports up to 16 dashboard items. Each item is linked to one of the sensors from the sensor list (I2C, 1-wire and analog sensors) and additional digital inputs and outputs.

Dashboard item types (with supported display types)

- 0: unused (inactive)
- 1: digital input (only display type 0)
- 2: digital output (only display types 0 and 1)
- 3: analog input
- ~~4: PoExtBus output~~ (only display types 0 and 1) *will be supported in the next release*
- 5: sensor input
- 6: digital counters
- 7: PoLL shared data

Display types

All analog displays have the resolution of 0.01 and the range of -327,68 to +327.67.

Display type	0	+1
<b>Digital displays</b>		
0	ON/OFF text value display	+ on/off buttons
<b>Analog displays - various</b>		
2	generic - no unit	+ bar graph
4	per second (s <sup>-1</sup> )	+ bar graph
6	per minute (min <sup>-1</sup> )	+ bar graph
8	rpm	+ bar graph
10	voltage in V	+ bar graph
12	current in mA	+ bar graph
14	current in A	+ bar graph
16	voltage in mV	+ bar graph
<b>Temperature</b>		
20	temperature in degrees C	+ bar graph
22	temperature in degrees F	+ bar graph
24	temperature in K	+ bar graph
30	relative humidity in % RH	+ bar graph
<b>Power</b>		
32	power in W	+ bar graph
34	power in kW	+ bar graph
36	power cons. In kWh	+ bar graph
<b>Volume</b>		
38	volume in cubic m	+ bar graph
40	volume in cubic feet	+ bar graph
42	volume in liters	+ bar graph
44	volume in gallon	+ bar graph
<b>Weight</b>		
50	weight in g	+ bar graph
52	weight in kg	+ bar graph
54	weight in t	+ bar graph
56	weight in oz	+ bar graph
58	weight in pound	+ bar graph
<b>Time</b>		
100	seconds	+ bar graph
102	minutes	+ bar graph
104	hours	+ bar graph
106	days	+ bar graph
<b>Pressure</b>		
120	pressure in kPa	+ bar graph
122	pressure in bar	+ bar graph
124	pressure in atm	+ bar graph

<b>126</b>	pressure in psi	+ bar graph
<b>128</b>	pressure in mm H <sub>2</sub> O	+ bar graph
<b>130</b>	pressure in Pa	+ bar graph

### Setup dashboard items

- byte 2: 0x71
- byte 3: dashboard item ID (set bit 7 to set the configuration)
- byte 4-6: reserved
- byte 7: request ID

If bit 7 of byte 3 is set, the following values must be also set:

- byte 9-16: dashboard item label
- byte 17: dashboard item type (see above)
- byte 18: sensor ID (or pin ID for digital input/output or output index for PoExtBus)
- byte 19: dashboard item display type (see the second list above)
- byte 20: access rights (bit mapped user access list – see web interface users chapter)
- byte 21-22: minimal value for progress bar display (MSB first)
- byte 23-24: maximal value for progress bar display

#### Returned packet:

- byte 2: 0x71
- byte 3-6: reserved
- byte 7: request ID
- byte 9-16: dashboard item label
- byte 17: dashboard item type (see above)
- byte 18: sensor ID (or pin ID for digital input/output or output index for PoExtBus)
- byte 19: dashboard item display type (see the second list above)
- byte 20: access rights (bit mapped user access list – see web interface users chapter)
- byte 21-22: minimal value for progress bar display
- byte 23-24: maximal value for progress bar display

## Dashboard items (series 57)

PoKeys57 series devices support up to 100 dashboard items. Each item can be linked to one of the following supported data sources:

- 0: unused (inactive)
- 1: digital input
- 2: digital output
- ~~3: analog input~~
- 4: PoExtBus output
- 5: sensor input
- 6: digital counters
- 7: PoL shared data

### Display types

Display type	ID	Parameter 1	Parameter 2
<b>Value display</b>	0	Bit 0: show bar graph Bit 1: show slider Bit 2: show text entry	
<b>On/Off display</b>	10	Bit 0: show on/off Bit 1: show toggle button	
<b>Gauge display</b>	20		

All analog displays have the resolution of 0.01 and the range of -327,68 to +327.67.

### Supported units

Unit ID	Unit display	Unit ID	Unit display
<b>0-2</b>	generic - no unit	10	voltage in V
<b>4</b>	per second ( $s^{-1}$ )	12	current in mA
<b>5</b>	per second (1/s)		
<b>6</b>	per minute ( $min^{-1}$ )	14	current in A
<b>7</b>	per minute (1/min)		
<b>8</b>	rpm	16	voltage in mV
<b>Temperature</b>			
<b>20</b>	temperature in degrees C	24	temperature in K
<b>22</b>	temperature in degrees F	30	relative humidity in %RH
		31	relative humidity in %
<b>Power</b>			
<b>32</b>	power in W	35	power cons. in Wh
<b>34</b>	power in kW	36	power cons. in kWh
<b>Volume</b>			
<b>38</b>	volume in cubic m	40	volume in cubic feet
<b>39</b>	volume flow in cubic m per second	41	volume flow in cubic feet per second
<b>42</b>	volume in liters	44	volume in gallon
<b>43</b>	volume flow in liters per second		
<b>Weight</b>			
<b>50</b>	weight in g	56	weight in oz
<b>52</b>	weight in kg	58	weight in pound
<b>54</b>	weight in t		
<b>Time</b>			
<b>100</b>	seconds	104	hours
<b>102</b>	minutes	106	days
<b>Pressure</b>			
<b>120</b>	pressure in kPa	126	pressure in psi

<b>122</b>	pressure in bar	124	pressure in atm
<b>130</b>	pressure in Pa	128	pressure in mm H <sub>2</sub> O
<b>Custom units</b>			
<b>200-219</b>	custom unit 0 - 19		

### *0x78/0x00 Dashboard item operation*

Byte	Function
<b>1 (header)</b>	Header (0xBB)
<b>2 (CMD)</b>	<b>0x78</b>
<b>3</b>	0x00 - dashboard item operation
<b>4</b>	Operation code: 0x00 - Read item 0x10 - Write item
<b>5</b>	Item index
<b>6</b>	Items num (1 or 2)
<b>7</b>	Request ID
<b>8 (CRC)</b>	CRC
<b>9</b>	Data source
<b>10</b>	Data source parameter
<b>11</b>	Display type
<b>12</b>	Unit
<b>13</b>	Display parameter 1
<b>14</b>	Display parameter 2
<b>15</b>	Access rights (bit mapped user access list – see web interface users chapter)
<b>16-28</b>	Label (13 bytes)
<b>29-32</b>	Minimum value (32-bit)
<b>33-36</b>	Maximum value (32-bit)
<b>37-64</b>	Repeated bytes 9-36 for second item if byte 6 set to 2

### Dashboard item operation - Response

Byte	Function
<b>1 (header)</b>	Header (0xAA)
<b>2 (CMD)</b>	<b>0x78</b>
<b>3</b>	0x00 - dashboard item operation
<b>4</b>	Operation code: 0x00 - Read item 0x10 - Write item
<b>5</b>	Item index
<b>6</b>	Items num (1 or 2)
<b>7</b>	Request ID
<b>8 (CRC)</b>	CRC
<b>9</b>	Data source
<b>10</b>	Data source parameter
<b>11</b>	Display type
<b>12</b>	Unit
<b>13</b>	Display parameter 1
<b>14</b>	Display parameter 2
<b>15</b>	Access rights
<b>16-28</b>	Label (13 bytes)

<b>29-32</b>	Minimum value (32-bit)
<b>33-36</b>	Maximum value (32-bit)
<b>37-64</b>	Repeated bytes 9-36 for second item if byte 6 set to 2

### *0x78/0x80 Custom unit operation*

Byte	Function
<b>1 (header)</b>	Header (0xBB)
<b>2 (CMD)</b>	<b>0x78</b>
<b>3</b>	0x80 - custom unit operation
<b>4</b>	Operation code: 0x00 - Read unit 0x10 - Write unit
<b>5</b>	Unit index
<b>6</b>	Reserved
<b>7</b>	Request ID
<b>8 (CRC)</b>	CRC
<b>9-16</b>	Unit simple name (8 characters)
<b>17-48</b>	Unit HTML code (32 characters)
<b>49-63</b>	unused / reserved
<b>64 (CRC 2)</b>	CRC

### Custom unit operation - Response

Byte	Function
<b>1 (header)</b>	Header (0xAA)
<b>2 (CMD)</b>	<b>0x78</b>
<b>3</b>	0x80 - custom unit operation
<b>4</b>	Operation code
<b>5</b>	Unit index
<b>6</b>	Reserved
<b>7</b>	Request ID
<b>8 (CRC)</b>	CRC
<b>9-16</b>	Unit simple name (8 characters)
<b>17-48</b>	Unit HTML code (32 characters)
<b>49-63</b>	unused / reserved
<b>64 (CRC 2)</b>	CRC

### Sensor list (only for PoKeys56E/PoKeys56U)

Subsystem of PoKeys56E that automatically reads various sensors on I2C and 1-wire buses. It supports up to 10 I2C (IDs from 0 to 9) and up to 10 1-wire sensors (IDs from 10 to 19) and up to 7 analog sensors (IDs from 20 to 26).

Supported sensor types (I2C):

- 0x10: LM75 temperature sensor
- 0x20: SHT21 temperature
- 0x21: SHT32 humidity
- 0x30: MCP3425 with PGA = 1
- 0x31: MCP3425 with PGA = 2
- 0x32: MCP3425 with PGA = 4
- 0x33: MCP3425 with PGA = 8

Supported sensor types (1-wire):

- 0x28: DS18B20

Analog sensors

Analog sensors can be attached to PoKeys to a properly configured analog input pin. The measured value is then transformed according to the following formula:

$$u = AD_{val} * \frac{A_{gain}}{4096} + A_{offset}$$

Where  $AD_{val}$  is a measurement of the analog-to-digital converter (a value between 0 and 4095),  $A_{gain}$  is gain (16-bit integer number) and  $A_{offset}$  is result offset (16-bit integer number).

Handling off-line sensors:

If sensor is detected as being offline, the various default values can be specified:

- Bit 7: set the value to 0xFFFFFFFF
- Bit 6: set the value to 0
- Bits 0-5: sensor timeout value (in s)

### Setup sensors

- byte 2: 0x70
- byte 3: sensor ID (set bit 7 to set the configuration)
- byte 4: offline sensor configuration byte (see above for description)
- byte 5-6: reserved
- byte 7: request ID

For each sensor connection type:

*Sensor IDs 0 to 9 (I2C sensor):*

- byte 9: Sensor type (see above list of supported I2C sensors)
- byte 10: I2C address of the sensor
- byte 11: Refresh period in 100 ms

*Sensor IDs 10 to 19 (1-wire sensor):*

- bytes 9-16: 64-bit 1-wire identifier
- byte 17: Refresh period in 100 ms

*Sensor IDs 20 to 26 (analog sensor):*

- byte 9: analog channel (pin ID 40-46)
- bytes 10-13: gain (MSB first) \* remark 25.11.2012: changed to 32-bit signed integers
- bytes 14-17: offset (MSB first) \* remark 25.11.2012: changed to 32-bit signed integers

**Returned packet:**

- byte 2: 0x70
- byte 3: reserved
- byte 4: offline sensor configuration byte (see above for description)
- byte 5-6: reserved
- byte 7: request ID

For each sensor connection type:

*Sensor connection type 0 (I2C sensor):*

- byte 9: Sensor type (see above list of supported I2C sensors)
- byte 10: I2C address of the sensor
- byte 11: Refresh period in 100 ms
- bytes 20-23: Sensor value (MSB first)

*Sensor connection type 1 (1-wire sensor):*

- bytes 9-16: 64-bit 1-wire identifier
- byte 17: Refresh period in 100 ms
- bytes 20-23: Sensor value (MSB first)

*Sensor connection type 2 (analog sensor):*

- byte 9: analog channel (pin ID 40-46)
- bytes 10-13: gain (MSB first)
- bytes 14-17: offset (MSB first)
- bytes 20-23: Sensor value (MSB first)

#### Read all sensors

- byte 2: 0x74
- byte 3: page index (0-2), sensor index (100-103)
- byte 4-6: reserved
- byte 7: request ID

#### Returned packet:

- byte 2: 0x74
- byte 3-6: reserved
- byte 7: request ID

Page indexes 0-1:

- bytes 9-12: sensor (index \* 14 + 1) value (MSB first)
- bytes 13-16: sensor (index \* 14 + 2) value (MSB first)
- ...
- bytes 57-60: sensor (index \* 14 + 13) value (MSB first)
- bytes 61-64: sensor (index \* 14 + 14) value (MSB first)

Sensor indexes 100-103:

- bytes 9-16: sensor ( (index-100) \* 7 + 1) 64-bit ID
- ...

## PoKeys EasySensors (PoKeys series 57)

Subsystem of PoKeys series 57 devices that automatically reads various sensors on I2C, 1-wire buses and analog inputs. Up to 100 sensors can be setup.

### Supported sensor types

Sensor	Sensor bus	Sensor type	Reading IDs	Sensor resolution
<b>LM75</b>	I <sup>2</sup> C	0x10	0 - temperature in °C	0.5 °C
<b>SHT21</b>	I <sup>2</sup> C	0x11	0 - temperature in °C 1 - humidity in %RH	0.01 °C 0.04 %RH
<b>DS18S20</b>	(Dallas) 1-wire	0x18	0 - temperature in °C	0.0625 °C
<b>DS18B20</b>	(Dallas) 1-wire	0x19	0 - temperature in °C	0.0625 °C
<b>DS2413</b>	(Dallas) 1-wire	0x1A	0 - digital input PIOA 2 - digital input PIOB	
<b>DHT11</b>	(DHTxx) 1-wire	0x20	0 - temperature in °C 1 - humidity in %RH	1 °C 1 %RH
<b>DHT21</b>	(DHTxx) 1-wire	0x21	0 - temperature in °C 1 - humidity in %RH	0.1 °C 0.1 %RH
<b>DHT22</b>	(DHTxx) 1-wire	0x22	0 - temperature in °C 1 - humidity in %RH	0.1 °C 0.1 %RH
<b>SI7020</b>	I <sup>2</sup> C	0x23	0 - temperature in °C 1 - humidity in %RH	0.01 °C 0.04 %RH
<b>BH1750</b>	I <sup>2</sup> C	0x40	0 - light intensity in lx	1 lx
<b>SI1141</b>	I <sup>2</sup> C	0x41	0 - light intensity (visible) - indoor 1 - light intensity (visible) - outdoor 2 - light intensity (IR) - indoor 3 - light intensity (IR) - outdoor  10 - light reflection	
<b>MCP3425</b>	I <sup>2</sup> C	0x50	0 - A/D input (1x gain) in μV 1 - A/D input (2x gain) in μV 2 - A/D input (4x gain) in μV 3 - A/D input (8x gain) in μV	62.50 μV 31.25 μV 15.63 μV 7.81 μV
<b>ADS1115</b>	I <sup>2</sup> C	0x51	bits 7-5: PGA setting (see ADS1115) bist 4-3: reserved bits 2-0: MUX setting (see ADS1115)	
<b>MMA7660</b>	I <sup>2</sup> C	0x60	0 - acceleration in axis x 1 - acceleration in axis y 2 - acceleration in axis z	
<b>Analog</b>	Analog input	0xF0	41 - analog input on pin 41 42 - analog input on pin 42 43 - analog input on pin 43 44 - analog input on pin 44 45 - analog input on pin 45 46 - analog input on pin 46 47 - analog input on pin 47	~0.8 mV ~0.8 mV ~0.8 mV ~0.8 mV ~0.8 mV ~0.8 mV ~0.8 mV

### Analog sensors

Various analog sensors can be attached to PoKeys (to one of the analog input pins). The measured value is then transformed according to the following formula:

$$u = AD_{val} * \frac{A_{gain}}{4096} + A_{offset}$$

Where  $AD_{val}$  is a measurement of the analog-to-digital converter (a value between 0 and 4095),  $A_{gain}$  is gain (32-bit integer number) and  $A_{offset}$  is result offset (32-bit integer number).

### Sensor failure (failsafe configuration)

If sensor is detected as being offline (the sensors has either failed or is disconnected), the various default values can be specified:

- Bit 7: set the value to 0x7FFFFFFF
- Bit 6: set the value to 0
- Bits 0-5: sensor timeout value (in s)

### Sensor item data structure

Each sensor entry is described by 4 fields - sensor type, sensor refresh period, failsafe configuration, sensor reading ID and sensor ID. Sensor type field contains the 'Sensor type' value from the table above, refresh period is specified in 0.1 second intervals, failsafe configuration byte is described above, sensor reading ID is also given in the table above. Sensor ID depends on the sensor's bus type and is structured as follows.

#### *I<sup>2</sup>C bus sensors*

ID byte 1	ID byte 2	ID byte 3	ID byte 4	ID byte 5	ID byte 6	ID byte 7	ID byte 8
sensor I <sup>2</sup> C address	unused	unused	unused	unused	unused	unused	unused

#### *(Dallas) 1-wire bus sensors*

ID byte 1	ID byte 2	ID byte 3	ID byte 4	ID byte 5	ID byte 6	ID byte 7	ID byte 8
PoKeys pin	56 bits of 64-bit Dallas 1-wire sensor ROM ID (without family ID)						

#### *(DHTxx) 1-wire bus sensors*

ID byte 1	ID byte 2	ID byte 3	ID byte 4	ID byte 5	ID byte 6	ID byte 7	ID byte 8
PoKeys pin	unused	unused	unused	unused	unused	unused	unused

#### *Analog sensors*

ID byte 1	ID byte 2	ID byte 3	ID byte 4	ID byte 5	ID byte 6	ID byte 7	ID byte 8
$A_{gain}$				$A_{offset}$			

### *0x76 Read / write sensors setup (series 57)*

Byte	Function
1 (header)	Header (0xBB)
2 (CMD)	0x76
3	Sensor index (0 - 99)
4	Sensor count (1 - 4)
5	Read (0) or write (1)
6	Reserved
7	Request ID
8 (CRC)	CRC
9	Sensor type
10	Sensor reading ID
11	Refresh period
12	Failsafe configuration

<b>13-20</b>	Sensor ID
...	repeat bytes 9 to 20 for each additional sensor
<b>x-63</b>	unused / reserved (depends on sensor count, x between 21 and 57)
<b>64 (CRC 2)</b>	CRC

Read / write sensors setup - Response

Byte	Function
<b>1 (header)</b>	Header (0xAA)
<b>2 (CMD)</b>	<b>0x76</b>
<b>3</b>	Sensor index (0 - 99)
<b>4</b>	Sensor count (1 - 4)
<b>5-6</b>	Reserved
<b>7</b>	Request ID
<b>8 (CRC)</b>	CRC
<b>9</b>	Sensor type
<b>10</b>	Sensor reading ID
<b>11</b>	Refresh period
<b>12</b>	Failsafe configuration
<b>13-20</b>	Sensor ID
...	repeat bytes 9 to 20 for each additional sensor
<b>x-63</b>	unused / reserved (depends on sensor count, x between 21 and 57)
<b>64 (CRC 2)</b>	CRC

*0x77 Read sensors values (series 57)*

Byte	Function
<b>1 (header)</b>	Header (0xBB)
<b>2 (CMD)</b>	<b>0x77</b>
<b>3</b>	Sensor index (0 - 99)
<b>4</b>	Sensor count (1 - 13)
<b>5-6</b>	Reserved
<b>7</b>	Request ID
<b>8 (CRC)</b>	CRC
<b>9-63</b>	unused / reserved
<b>64 (CRC 2)</b>	CRC

Read / write sensors setup - Response

Byte	Function
<b>1 (header)</b>	Header (0xAA)
<b>2 (CMD)</b>	<b>0x77</b>
<b>3</b>	Sensor index (0 - 99)
<b>4</b>	Sensor count (1 - 13)
<b>5-6</b>	Bit-mapped sensor status information (bit 0 of byte 5 - first sensor)
<b>7</b>	Request ID
<b>8 (CRC)</b>	CRC
<b>9</b>	Sensor value (LSB first)
<b>10</b>	repeat bytes 9 to 12 for each additional sensor
<b>11</b>	unused / reserved (depends on sensor count, x between 13 and 61)
<b>64 (CRC 2)</b>	CRC



## Cosm support settings (deprecated in 3.0.39 firmware).

In order to upload data to Cosm web service, user must specify Cosm API key and Feed ID strings. Also, Cosm server IP and update rate can be selected.

### Cosm settings

Byte	Function
<b>1 (header)</b>	Header (0xBB)
<b>2 (CMD)</b>	<b>0xEF</b>
<b>3</b>	<b>Operation code:</b> 0 – read general Cosm configuration 1 – read first 50 bytes of Cosm API key 2 – read second 50 bytes of Cosm API key  10 – set general Cosm configuration 11 – set first 50 bytes of Cosm API key 12 – set second 50 bytes of Cosm API key
<b>4</b>	Reserved
<b>5</b>	Reserved
<b>6</b>	Reserved
<b>7</b>	Request ID
<b>8 (CRC)</b>	CRC
<b>Set general Cosm configuration</b>	
<b>9</b>	Cosm update rate
<b>10-13</b>	Cosm server IP
<b>14-23</b>	Cosm Feed ID
<b>24-63</b>	Reserved
<b>Set first 50 bytes of Cosm API key</b>	
<b>9-58</b>	Cosm API key – first 50 bytes
<b>59-63</b>	Reserved
<b>Set second 50 bytes of Cosm API key</b>	
<b>9-58</b>	Cosm API key – second 50 bytes
<b>59-63</b>	Reserved
<b>64 (CRC 2)</b>	CRC

### Basic settings – Response

Byte	Function
<b>1 (header)</b>	Header (0xAA)
<b>2 (CMD)</b>	<b>0xEF</b>
<b>3</b>	Operation code
<b>4</b>	Reserved
<b>5</b>	Reserved
<b>6</b>	Reserved
<b>7</b>	Request ID
<b>8 (CRC)</b>	CRC
<b>Read general Cosm configuration</b>	
<b>9</b>	Cosm update rate
<b>10-13</b>	Cosm server IP
<b>14-23</b>	Cosm Feed ID
<b>24</b>	Last status code
<b>25-63</b>	Reserved
<b>Read first 50 bytes of Cosm API key</b>	

9-58	Cosm API key – first 50 bytes
59-63	Reserved
<b>Read second 50 bytes of Cosm API key</b>	
9-58	Cosm API key – second 50 bytes
59-63	Reserved
64 (CRC 2)	CRC

## Server reports settings

In order to upload data to various web services, user must specify request header, server IP and update rate. The request header is constructed of two parts – HTML header and data header, divided by double new line character (\n). Example header (Cosm.com web service):

<pre>PUT /v2/feeds/62592.csv HTTP/1.1 Host: api.cosm.com X-APIKey: CAb3XX634daSAKxZc3M0M3I1NWVZVT0g User-Agent: PoKeys56E Content-Type: text/csv Content-Length: 010 Connection: close  Test1234,-15000.00</pre>	<p>The HTTP header without 'Connection' and 'Content-length' tags must be provided by the user</p> <p>The 'Connection' and 'Content-length' tags are automatically inserted by PoKeys56E device</p> <p>Data is inserted at the end of the packet</p>
--	--

The above example is saved as

<pre>PUT /v2/feeds/62592.csv HTTP/1.1 Host: api.cosm.com X-APIKey: CAb3XX634daSAKxZc3M0M3I1NWVZVT0g User-Agent: PoKeys56E Content-Type: text/csv \n</pre>
---

The extra new line at the end is essential.

More customized header:

<pre>POST /myScript.php HTTP/1.1 Host: api.cosm.com User-Agent: MyCustomDeviceAgent Content-Type: text/csv Content-Length: 010 Connection: close  MyData: Test1234,-15000.00</pre>	<p>The HTTP header without 'Connection' and 'Content-length' tags must be provided by the user</p> <p>The 'Connection' and 'Content-length' tags are automatically inserted by PoKeys56E device</p>
--	---

The above example is saved as

<pre>POST /myScript.php HTTP/1.1 Host: api.cosm.com User-Agent: MyCustomDeviceAgent Content-Type: text/csv \n MyData:</pre>
---

Again, an extra new line character in fifth line is essential.

Total length of final header and data is limited to 350 bytes.

### Server reports settings

Byte	Function
<b>1 (header)</b>	Header (0xBB)
<b>2 (CMD)</b>	<b>0xEF</b>
<b>3</b>	<b>Operation code:</b> 0 – read server IP, update rate, request type 1–5 – read request header (50 bytes per request)  10 – set server IP, update rate, request type 11-15 – set request header (50 bytes per request)
<b>4</b>	Reserved
<b>5</b>	Reserved
<b>6</b>	Reserved
<b>7</b>	Request ID
<b>8 (CRC)</b>	CRC
<b>Operation 10</b>	
<b>9-10</b>	Update rate
<b>11-14</b>	Server IP
<b>15</b>	Request type bit 7:5: internal type reference (set to 0 if setting the fields manually) 0 - Cosm/Xively, 1 - POST, 2 - PUT, 3 - Custom, 4 - UDP mode  bit 4: source selection 0 - sensor's values 1 - UART buffer  bit 3:2: value type 0 - CSV, each variable in its own line, variable name and variable value delimited with comma in each line 1 - CSV, all variables in one line in format {variableName},{variable} 2 - same as 1 but with   as delimiter 3 - JSON format  bit 1:0: protocol selection 0 - specified HTTP header 1 - RAW data
<b>16-17</b>	Server port number
<b>18-63</b>	Reserved
<b>Operations 11-15</b>	
<b>9-58</b>	Request header – 50 bytes (operation number selects page index)
<b>59-63</b>	Reserved
<b>64 (CRC 2)</b>	CRC

### Server reports settings – Response

Byte	Function
<b>1 (header)</b>	Header (0xAA)
<b>2 (CMD)</b>	<b>0xEF</b>
<b>3</b>	Operation code
<b>4</b>	Reserved
<b>5</b>	Reserved
<b>6</b>	Reserved
<b>7</b>	Request ID
<b>8 (CRC)</b>	CRC

<b>Operation 0</b>	
<b>9-10</b>	Update rate
<b>11-14</b>	Server IP
<b>15</b>	Request type
<b>16-17</b>	Last status code
<b>18-19</b>	Server port number
<b>20-63</b>	Reserved
<b>Operations 1-5</b>	
<b>9-58</b>	Request header – 50 bytes (operation number selects page index)
<b>59-63</b>	Reserved
<b>64 (CRC 2)</b>	CRC



## Pulse engine commands (not supported since FW version 3.0.66)

(this module must be activated before first use with the activation code supplied by the manufacturer)

### Constants used

#### Pulse engine states

peSTOPPED	= 0,
peINTERNAL	= 1,
peBUFFER	= 2,
peJOGGING	= 10,
peSTOPPING	= 11,
peHOME	= 20,
peHOMING	= 21,
peSTOP_LIMIT	= 100,
peSTOP_EMERGENCY	= 101

#### Axis states

axSTOPPED	= 0,
axREADY	= 1,
axRUNNING	= 2,
axHOME	= 10,
axHOMINGSTART	= 11,
axHOMINGSEARCH	= 12,
axHOMINGBACK	= 13,
axERROR	= 20,
axLIMIT	= 30,

### Get status (position, limits, home, ...)

- byte 2: 0x80
- byte 3: 0x00
- byte 4: 0
- byte 5: 0
- byte 6: 0
- byte 7: request ID

#### Returned packet:

- byte 2: 0x80
- byte 3: 0x00
- byte 4-6: 0
- byte 7: request ID
  
- byte 9-12: x position
- byte 13-16: y position

- byte 17-20: z position
- byte 21: limits+ status (bit mapped, x+=bit 0; y+=bit 1; z+=bit 2;
- byte 22: limits- status (bit mapped, x-=bit 4; y-=bit 5; z-=bit 6)
- byte 23: home status (bit mapped, x0=bit 0; 0+=bit 1; z0=bit 2)
- byte 24: pulse engine state
- byte 25: x axis state
- byte 26: y axis state
- byte 27: z axis state
- byte 28: pulse engine enabled
- byte 29: safety charge pump enabled
- bytes 30-49: axes 4-8 position
- bytes 50-54: axes 4-8 state

### *Set current position*

- byte 2: 0x80
- byte 3: 0x01
- byte 4: 0
- byte 5: 0
- byte 6: 0
- byte 7: request ID
  
- byte 9-12: x position
- byte 13-16: y position
- byte 17-20: z position
- byte 21-40: axes 4-8 position

#### Returned packet:

- byte 2: 0x80
- byte 3: 0x01
- byte 4-6: 0
- byte 7: request ID

### *Set current pulse engine state*

- byte 2: 0x80
- byte 3: 0x02
- byte 4: 0
- byte 5: 0
- byte 6: 0
- byte 7: request ID
  
- byte 9: mode

#### Returned packet:

- byte 2: 0x80
- byte 3: 0x02
- byte 4-6: 0

- byte 7: request ID

### *Set MPG jogging options*

- byte 2: 0x80
- byte 3: 0x03
- byte 4: 0 to read the configuration, 10 to write it
- byte 5: 0
- byte 6: 0
- byte 7: request ID
  
- byte 9: MPG jog activated
- bytes 10-13: MPG jog multiplier X
- bytes 14-17: MPG jog multiplier Y
- bytes 18-21: MPG jog multiplier Z
- byte 22: Axis X encoder ID+1 (0 disables the MPG jogging for the axis)
- byte 23: Axis Y encoder ID+1 (0 disables the MPG jogging for the axis)
- byte 24: Axis Z encoder ID+1 (0 disables the MPG jogging for the axis)
- bytes 25-44: MPG jog multipliers for axes 4-8
- bytes 45-49: Axes 4-8 encoder ID+1 (0 disables the MPG jogging for the axis)

### **Returned packet:**

- byte 2: 0x80
- byte 3: 0x03
- byte 4-6: 0
- byte 7: request ID
- byte 9: MPG jog activated
- bytes 10-13: MPG jog multiplier X
- bytes 14-17: MPG jog multiplier Y
- bytes 18-21: MPG jog multiplier Z
- byte 22: Axis X encoder ID+1 (0 disables the MPG jogging for the axis)
- byte 23: Axis Y encoder ID+1 (0 disables the MPG jogging for the axis)
- byte 24: Axis Z encoder ID+1 (0 disables the MPG jogging for the axis)
- bytes 25-44: MPG jog multipliers for axes 4-8
- bytes 45-49: Axes 4-8 encoder ID+1 (0 disables the MPG jogging for the axis)

### *Set reference position*

- byte 2: 0x80
- byte 3: 0x05
- byte 4: mode (0 for position reference, 10 for speed reference)
- byte 5: 0
- byte 6: 0
- byte 7: request ID
  
- byte 9-12: reference x position
- byte 13-16: reference y position
- byte 17-20: reference z position
- bytes 21-40: reference position for axes 4-8

**Returned packet:**

- byte 2: 0x80
- byte 3: 0x05
- byte 4-6: 0
- byte 7: request ID

***Enable/disable pulse engine (read with command 0x80, 0x00)***

- byte 2: 0x80
- byte 3: 0x06
- byte 4: enabled (1) / disabled (0)
- byte 5: activate safety charge pump output on pin 53
- bytes 6: 0
- byte 7: request ID

***Get parameters***

- byte 2: 0x80
- byte 3: 0x10
- byte 4: 0 for parameters for axes 1-3, 1 for axes 4-6, 2 for axes 7-8
- byte 5: 0
- byte 6: 0
- byte 7: request ID

**Returned packet:**

- byte 2: 0x80
- byte 3: 0x10
- byte 4-6: 0
- byte 7: request ID
  
- byte 9-20: max speed for x,y,z (32-bit float for each axis) - speed / 1ms
- byte 21-32: max acceleration for x,y,z (32-bit float for each axis) - acc / 1ms \* 1ms
- byte 33-44: max deceleration for x,y,z (32-bit float for each axis) - acc / 1ms \* 1ms
- byte 45: Homing speed in % of maximum speed
- byte 46: Homing return speed in % of maximum speed
- byte 47: Emergency switch polarity selection:
  - 0 – HIGH state activates the emergency
  - 1 – LOW state activates the emergency

***Set parameters***

- byte 2: 0x80
- byte 3: 0x11
- byte 4: 0
- byte 5: 0
- byte 6: 0
- byte 7: request ID

- byte 9-20: max speed for x,y,z (32-bit float for each axis) - speed / 1ms
- byte 21-32: max acceleration for x,y,z (32-bit float for each axis) - acc / 1ms \* 1ms
- byte 33-44: max deceleration for x,y,z (32-bit float for each axis) - acc / 1ms \* 1ms
- byte 45: Homing speed in % of maximum speed
- byte 46: Homing return speed in % of maximum speed
- byte 47: Emergency switch polarity selection
  - 0 – HIGH state activates the emergency
  - 1 – LOW state activates the emergency

**Returned packet:**

- byte 2: 0x80
- byte 3: 0x11
- byte 4-6: 0
- byte 7: request ID

*Get axes parameters*

- byte 2: 0x80
- byte 3: 0x12
- bytes 4-6: 0
- byte 7: request ID

**Returned packet:**

- byte 2: 0x80
- byte 3: 0x12
- byte 4-6: 0
- byte 7: request ID
  
- byte 9: limit+ switches configuration (bits 0,1,2 - axes x,y,z)
- byte 10: limit- switches configuration (bits 0,1,2 - axes x,y,z)
- byte 11: home switches configuration (bits 0,1,2 - axes x,y,z)
- byte 12: direction change (bits 0,1,2 - axes x,y,z)
- byte 13: homing direction change (bits 0,1,2 - axes x,y,z)

*Set axes parameters*

- byte 2: 0x80
- byte 3: 0x13
- bytes 4-6: 0
- byte 7: request ID
  
- byte 9: limit+ switches configuration (bits 0,1,2 - axes x,y,z)
- byte 10: limit- switches configuration (bits 0,1,2 - axes x,y,z)
- byte 11: home switches configuration (bits 0,1,2 - axes x,y,z)
- byte 12: direction change (bits 0,1,2 - axes x,y,z)
- byte 13: homing direction change (bits 0,1,2 - axes x,y,z)

### *Get controller setup*

- byte 2: 0x80
- byte 3: 0x14
- bytes 4-6: 0
- byte 7: request ID

#### **Returned packet:**

- byte 2: 0x80
- byte 3: 0x14
- byte 4-6: 0
- byte 7: request ID

- byte 9: CNC keyboard enabled status - 1 if keyboard is enabled if detected

### *Set CNC keyboard setup*

- byte 2: 0x80
- byte 3: 0x15
- bytes 4-6: 0
- byte 7: request ID

- byte 9: CNC keyboard enabled status - 1 if keyboard is enabled if detected

### *Execute homing*

- byte 2: 0x80
- byte 3: 0x20
- byte 4: 0
- byte 5: 0
- byte 6: 0
- byte 7: request ID

- byte 9-11: x,y,z homing status (set to 1 to home the axis)

#### **Returned packet:**

- byte 2: 0x80
- byte 3: 0x20
- byte 4-6: 0
- byte 7: request ID

### *Get engine info*

- byte 2: 0x80
- byte 3: 0x30
- byte 4-6: 0
- byte 7: request ID

**Returned packet:**

- byte 2: 0x80
- byte 3: 0x30
- byte 4-6: 0
- byte 7: request ID
  
- byte 9: number of axes supported
- byte 10: maximum pulse frequency in kHz
- byte 11: buffer size
- byte 12: slot timing (in x100 us)

**Fill buffer**

- byte 2: 0x80
- byte 3: 0x35
- byte 4: number of new entries
- byte 5-6: 0
- byte 7: request ID
  
- bytes 9-64: buffer entries (one byte per axis) – 0xFF (-127) for axis x is special command

**Returned packet:**

- byte 2: 0x80
- byte 3: 0x35
- byte 4-6: 0
- byte 7: request ID
  
- byte 9: number of entries accepted
- byte 10-13: x position
- byte 14-17: y position
- byte 18-21: z position
- byte 22: limits+ status (bit mapped, x+=bit 0; y+=bit 1; z+=bit 2;
- byte 23: limits- status (bit mapped, x-=bit 4; y-=bit 5; z-=bit 6)
- byte 24: home status (bit mapped, x0=bit 0; 0+=bit 1; z0=bit 2)
- byte 25: pulse engine state
- byte 26: x axis state
- byte 27: y axis state
- byte 28: z axis state

**Clear buffer**

- byte 2: 0x80
- byte 3: 0x36
- byte 4-6: 0
- byte 7: request ID

### *Get buffer size*

- byte 2: 0x80
- byte 3: 0x37
- byte 4-6: 0
- byte 7: request ID

### **Returned packet:**

- byte 2: 0x80
- byte 3: 0x37
- byte 4-6: 0
- byte 7: request ID
  
- byte 9: buffer size



## Pulse engine commands v2

Pulse engine v2 supports two different pulse generator modules:

- Internal: similar to basic Pulse engine, limited to 25 kHz pulse frequency at 3 channels, uses built-in circuitry and pins
- External: new in v2, limited to 125 kHz pulse frequency at 8 channels, requires external circuitry to deserialize the data to pulses
- Smart external

Fast outputs

- Axes with 'Fast output' option activated, have no motion capability, but can be used to drive an auxiliary load quickly (laser cutter)

## Constants used

Pulse engine states

peSTOPPED	= 0,
peINTERNAL	= 1,
peBUFFER	= 2,
peRUNNING	= 3,
peJOGGING	= 10,
peSTOPPING	= 11,
peHOME	= 20,
peHOMING	= 21,
pePROBECOMPLETE	= 30,
pePROBING	= 31,
pePROBEERROR	= 32,
peSTOP_LIMIT	= 100,
peSTOP_EMERGENCY	= 101

Axis states

axSTOPPED	= 0,
axREADY	= 1,
axRUNNING	= 2,
axBUFFER	= 5,
axHOME	= 10,
axHOMINGSTART	= 11,
axHOMINGSEARCH	= 12,
axHOMINGBACK	= 13,
axPROBED	= 14,
axPROBESTART	= 15,
axPROBESEARCH	= 16,
axERROR	= 20,
axLIMIT	= 30,



### 0x85/0x00 Get status (position, limits, home, ...)

Request

Byte	Function
1 (header)	Header (0xBB)
2 (CMD)	0x85
3	0x00 - Get status
4	Check byte
5	Reserved
6	Reserved
7	Request ID
8 (CRC)	CRC
9-63	Reserved
64 (CRC 2)	unused

Response

Byte	Function
1 (header)	Header (0xAA)
2 (CMD)	0x85
3	0x00 - Status message
4	Soft limit status (bit-mapped, one bit per axis)
5	States with enabled power
6	Limit override status
7	Request ID
8 (CRC)	CRC
9	Pulse engine enabled - number of enabled axes
10	Pulse engine initialized (activated) status
11	Pulse engine state
12	Safety charge pump enabled
13	Limit+ switch status (bit mapped, one bit per axis)
14	Limit- switch status (bit mapped, one bit per axis)
15	Home switch status (bit mapped, one bit per axis)
16	Pulse generator type bits 0-3: generator type (0 - 8ch external, 1 - 3ch internal, 2 - 8ch smart external) bits 4-5: reserved bit 6: swap step / dir signals bit 7: use external extended IO features (only for external pulse generator)
17-24	Axes status (8x 8-bit, values listed above)
25-56	Axes positions (8x 32-bit, LSB first)
57	Maximum number of axes supported
58	Maximum pulse frequency in kHz
59	Motion buffer size (number of available time slots)
60	Slot timing (in 100us steps)
61	Emergency switch polarity
62	External error inputs status (bit-mapped to axes)
63	External misc inputs status (bit 4 = input 5, bit 5 = input 6, bit 6 = input 7, bit 7 = spindle error input)
64 (CRC 2)	0x5A + check byte from request

### 0x85/0x01 Setup pulse engine

Request

Byte	Function
1 (header)	Header (0xBB)
2 (CMD)	0x85
3	0x01 - Setup pulse engine
4	Reserved
5	Reserved
6	Reserved
7	Request ID
8 (CRC)	CRC
9	Pulse engine enabled - number of enabled axes
10	Safety charge pump enabled
11	Pulse generator configuration bits 0-3: Pulse generator type (0 - 8ch external, 1 - 3ch internal) bits 4-5: reserved bit 6: swap step / dir signals bit 7: is used to enable or disable external inputs&outputs
12	Motion buffer size (0 - default value)
13	Emergency switch inverted polarity
14	States with enabled power (bit-mapped): bit 0: peSTOPPED bit 1: peSTOP_LIMIT bit 2: peSTOP_EMERGENCY States with enabled charge pump (bit-mapped) bit 4: peSTOPPED bit 5: peSTOP_LIMIT bit 6: peSTOP_EMERGENCY
15-63	Reserved
64 (CRC 2)	unused

Response

Byte	Function
1 (header)	Header (0xAA)
2 (CMD)	0x85
3	0x01 - Setup pulse engine
4	Command result (0 - OK)
5	Reserved
6	Reserved
7	Request ID
8 (CRC)	CRC
9-63	reserved
64 (CRC 2)	unused

### 0x85/0x02 Set state

Request

Byte	Function
1 (header)	Header (0xBB)
2 (CMD)	0x85
3	0x02 - Set state
4	Pulse engine state
5	Limit override option
6	Output enable mask (bit-mapped, 1 = enable axis output enable control), must be enabled in axis settings aoENABLED_MASKED
7	Request ID
8 (CRC)	CRC
9-63	Reserved
64 (CRC 2)	unused

Response

Byte	Function
1 (header)	Header (0xAA)
2 (CMD)	0x85
3	0x02 - Set state
4	Reserved
5	Reserved
6	Reserved
7	Request ID
8 (CRC)	CRC
9-63	reserved
64 (CRC 2)	unused

### 0x85/0x03 Set axis position

Request

Byte	Function
1 (header)	Header (0xBB)
2 (CMD)	0x85
3	0x03 - Set axis position
4	Axis position setup selection (bit-mapped)
5-6	Reserved
7	Request ID
8 (CRC)	CRC
9-40	Axis positions (32-bit LSB first)
41-63	Reserved
64 (CRC 2)	unused

Response

Byte	Function
1 (header)	Header (0xAA)
2 (CMD)	0x85
3	0x03 - Set axis position
4	Reserved
5	Reserved
6	Reserved
7	Request ID

<b>8 (CRC)</b>	unused
<b>9-63</b>	reserved
<b>64 (CRC 2)</b>	CRC

### *0x85/0x04 Set outputs (using PoKeysCNCaddon)*

Request

Byte	Function
<b>1 (header)</b>	Header (0xBB)
<b>2 (CMD)</b>	<b>0x85</b>
<b>3</b>	0x04 - Set outputs
<b>4</b>	Relay outputs (bit 0 = relay 1, bit 1 = relay 2, bit 2 = relay 3)
<b>5</b>	OC outputs (bit 3 = OC 1, bit 4 = OC 2, bit 5 = OC 3, bit 6 = OC 4)
<b>6</b>	If set to 1, the above output values are not used - read function
<b>7</b>	Request ID
<b>8 (CRC)</b>	CRC
<b>9-63</b>	Reserved
<b>64 (CRC 2)</b>	unused

Response

Byte	Function
<b>1 (header)</b>	Header (0xAA)
<b>2 (CMD)</b>	<b>0x85</b>
<b>3</b>	0x04 - Set outputs
<b>4</b>	Relay outputs
<b>5</b>	OC outputs
<b>6</b>	Reserved
<b>7</b>	Request ID
<b>8 (CRC)</b>	CRC
<b>9-63</b>	reserved
<b>64 (CRC 2)</b>	unused

### *0x85/0x04 Set outputs (using PoKeys57CNC)*

Request

Byte	Function
<b>1 (header)</b>	Header (0xBB)
<b>2 (CMD)</b>	<b>0x85</b>
<b>3</b>	0x04 - Set outputs
<b>4</b>	Reserved
<b>5</b>	bit 0: SSR 2 bit 1: Relay 2 bit 2: Relay 1 bit 3: OC 1 bit 4: OC 2 bit 5: OC 3 bit 6: OC 4 bit 7: SSR 1
<b>6</b>	If set to 1, the above output values are not used - read function
<b>7</b>	Request ID
<b>8 (CRC)</b>	CRC
<b>9-63</b>	Reserved
<b>64 (CRC 2)</b>	unused

Response

Byte	Function
1 (header)	Header (0xAA)
2 (CMD)	0x85
3	0x04 - Set outputs
4	Reserved
5	Outputs statuses as specified in the request
6	Reserved
7	Request ID
8 (CRC)	CRC
9-63	reserved
64 (CRC 2)	unused

### *0x85/0x05 Reboot pulse engine*

Request

Byte	Function
1 (header)	Header (0xBB)
2 (CMD)	0x85
3	0x05 - Reboot pulse engine
4-6	reserved
7	Request ID
8 (CRC)	CRC
9-63	Reserved
64 (CRC 2)	unused

Response

Byte	Function
1 (header)	Header (0xAA)
2 (CMD)	0x85
3	0x05 - Reboot pulse engine
4-6	Reserved
7	Request ID
8 (CRC)	CRC
9-63	reserved
64 (CRC 2)	unused

### *0x85/0x08 Get status 2*

Request

Byte	Function
1 (header)	Header (0xBB)
2 (CMD)	0x85
3	0x08 - Get status 2
4	Reserved
5	Reserved
6	Reserved
7	Request ID
8 (CRC)	CRC



<b>4</b>	enabled flag
<b>5</b>	source axis ID (0 to 7)
<b>6</b>	destination PWM channel ID (0 to 5)
<b>7</b>	Request ID
<b>8 (CRC)</b>	CRC
<b>9-63</b>	reserved
<b>64 (CRC 2)</b>	unused



### 0x85/0x10 Get axis configuration

Request

Byte	Function
1 (header)	Header (0xBB)
2 (CMD)	0x85
3	0x10 - Get axis configuration
4	Axis ID
5	Reserved
6	Reserved
7	Request ID
8 (CRC)	CRC
9-63	Reserved
64 (CRC 2)	unused

Response

Byte	Function
1 (header)	Header (0xAA)
2 (CMD)	0x85
3	0x10 - Get axis configuration
4	Reserved
5	Reserved
6	Reserved
7	Request ID
8 (CRC)	CRC
9	Axis options aoENABLED = (1<<0), aoINVERTED = (1<<1), aoINTERNAL_PLANNER = (1<<2), aoPOSITION_MODE = (1<<3), aoINVERTED_HOME = (1<<4), aoSOFT_LIMIT_ENABLED = (1<<5), aoFAST_OUTPUT = (1<<6), aoENABLED_MASKED = (1<<7)
10	Axis switch options aoSWITCH_LIMIT_N = (1<<0), aoSWITCH_LIMIT_P = (1<<1), aoSWITCH_HOME = (1<<2), aoSWITCH_COMBINED_LN_H = (1<<3), aoSWITCH_COMBINED_LP_H = (1<<4), aoSWITCH_INVERT_LIMIT_N = (1<<5), aoSWITCH_INVERT_LIMIT_P = (1<<6), aoSWITCH_INVERT_HOME = (1<<7)
11	Home switch input pin (0 for external)
12	Limit- switch input pin (0 for external)
13	Limit+ switch input pin (0 for external)
14	Homing speed (in % of the maximum speed)
15	Homing return (fine positioning) speed (in % of the homing speed)
16	MPG jog encoder ID
17-20	Axis maximum speed in timeslot units (32-bit float)
21-24	Axis maximum acceleration in timeslot units (32-bit float)
25-28	Axis maximum deceleration (braking) in timeslot units (32-bit float)
29-32	Soft-limit minimum position
33-36	Soft-limit maximum position

<b>37-38</b>	MPG jog multiplier
<b>39</b>	Axis enable output pin (0 for external)
<b>40</b>	Invert axis enable signal
<b>40-63</b>	reserved
<b>64 (CRC 2)</b>	unused

### 0x85/0x11 Set axis configuration

Request

Byte	Function
<b>1 (header)</b>	Header (0xBB)
<b>2 (CMD)</b>	<b>0x85</b>
<b>3</b>	0x11 - Set axis configuration
<b>4</b>	Axis ID
<b>5</b>	Reserved
<b>6</b>	Reserved
<b>7</b>	Request ID
<b>8 (CRC)</b>	CRC
<b>9</b>	Axis options aoENABLED = (1<<0), aoINVERTED = (1<<1), aoINTERNAL_PLANNER = (1<<2), aoPOSITION_MODE = (1<<3), aoINVERTED_HOME = (1<<4), aoSOFT_LIMIT_ENABLED = (1<<5), aoENABLED_MASKED = (1<<7)
<b>10</b>	Axis switch options aoSWITCH_LIMIT_N = (1<<0), aoSWITCH_LIMIT_P = (1<<1), aoSWITCH_HOME = (1<<2), aoSWITCH_COMBINED_LN_H = (1<<3), aoSWITCH_COMBINED_LP_H = (1<<4), aoSWITCH_INVERT_LIMIT_N = (1<<5), aoSWITCH_INVERT_LIMIT_P = (1<<6), aoSWITCH_INVERT_HOME = (1<<7)
<b>11</b>	Home switch input pin (0 for external)
<b>12</b>	Limit- switch input pin (0 for external)
<b>13</b>	Limit+ switch input pin (0 for external)
<b>14</b>	Homing speed (in % of the maximum speed)
<b>15</b>	Homing return (fine positioning) speed (in % of the homing speed)
<b>16</b>	MPG jog encoder ID
<b>17-20</b>	Axis maximum speed in timeslot units (32-bit float)
<b>21-24</b>	Axis maximum acceleration in timeslot units (32-bit float)
<b>25-28</b>	Axis maximum deceleration (braking) in timeslot units (32-bit float)
<b>29-32</b>	Soft-limit minimum position
<b>33-36</b>	Soft-limit maximum position
<b>37-38</b>	MPG jog multiplier
<b>39</b>	Axis enable output pin (0 for external)
<b>40</b>	Invert axis enable signal
<b>41-63</b>	reserved
<b>64 (CRC 2)</b>	unused

Response

Byte	Function
<b>1 (header)</b>	Header (0xAA)
<b>2 (CMD)</b>	<b>0x85</b>
<b>3</b>	0x11 - Set axis configuration
<b>4</b>	Reserved
<b>5</b>	Reserved
<b>6</b>	Reserved
<b>7</b>	Request ID
<b>8 (CRC)</b>	CRC
<b>9-63</b>	reserved
<b>64 (CRC 2)</b>	unused

### *0x85/0x20 Move (Set reference position or speed)*

Request

Byte	Function
1 (header)	Header (0xBB)
2 (CMD)	0x85
3	0x20 - set reference position or speed
4	Reserved
5	Reserved
6	Reserved
7	Request ID
8 (CRC)	CRC
9-40	Reference position or speed (8x 32-bit integer, LSB first)
41-63	reserved
64 (CRC 2)	unused

Response

Byte	Function
1 (header)	Header (0xAA)
2 (CMD)	0x85
3	0x20 - set reference position or speed
4	Reserved
5	Reserved
6	Reserved
7	Request ID
8 (CRC)	CRC
9-63	reserved
64 (CRC 2)	unused

### *0x85/0x21 Start homing*

Request

Byte	Function
1 (header)	Header (0xBB)
2 (CMD)	0x85
3	0x21 - Start homing
4	Bit-mapped axis selection
5-6	Reserved
7	Request ID
8 (CRC)	CRC
9-40	Home position offsets (32-bit LSB first pe axis)
41-63	Reserved
64 (CRC 2)	unused

Response

Byte	Function
1 (header)	Header (0xAA)
2 (CMD)	0x85
3	0x21 - Start homing
4-6	Reserved
7	Request ID
8 (CRC)	CRC
9-63	reserved

64 (CRC 2)	unused
------------	--------

### *0x85/0x22 Finish homing*

Request

Byte	Function
1 (header)	Header (0xBB)
2 (CMD)	0x85
3	0x22 - Finish homing
4	Pulse engine mode to transition into
5	Skip the pulse engine mode transition if this is set to > 0
6	Reserved
7	Request ID
8 (CRC)	CRC
9-63	Reserved
64 (CRC 2)	unused

Response

Byte	Function
1 (header)	Header (0xAA)
2 (CMD)	0x85
3	0x22 - Finish homing
4-6	Reserved
7	Request ID
8 (CRC)	CRC
9-63	reserved
64 (CRC 2)	unused

### *0x85/0x23 Start probing*

Request

Byte	Function
1 (header)	Header (0xBB)
2 (CMD)	0x85
3	0x23 - Start probing
4	Bit-mapped axis selection
5	Enable hybrid probing (ignore bytes 4 and 9-44)
6	Reserved
7	Request ID
8 (CRC)	CRC
9-40	Probe maximum position (32-bit LSB first per axis)
41-44	Probe speed (ration of the maximum speed - 0.01 equals to 1% of max. speed) - 32-bit float
45	Probe input (0 - disabled, 1-8 external inputs, 9+ PoKeys pin ID + 9)
46	Probe input polarity
47-63	Reserved
64 (CRC 2)	unused

Response

Byte	Function
1 (header)	Header (0xAA)
2 (CMD)	0x85
3	0x23 - Start probing

4-6	Reserved
7	Request ID
8 (CRC)	CRC
9-63	reserved
64 (CRC 2)	unused

### *0x85/0x24 Finish probing*

Request

Byte	Function
1 (header)	Header (0xBB)
2 (CMD)	0x85
3	0x24 - Finish probing
4	Action (0 - normal finish, 1 - just clear probing state)
5-6	Reserved
7	Request ID
8 (CRC)	CRC
9-63	Reserved
64 (CRC 2)	unused

Response

Byte	Function
1 (header)	Header (0xAA)
2 (CMD)	0x85
3	0x24 - Finish probing
4-6	Reserved
7	Request ID
8 (CRC)	CRC
9-40	Probe position
41	Probe status (probe completion bit-mapped status)
41-63	reserved
64 (CRC 2)	unused

### *0x85/0xF0 Clear motion buffer*

Request

Byte	Function
1 (header)	Header (0xBB)
2 (CMD)	0x85
3	0xF0 - Clear buffer
4-6	Reserved
7	Request ID
8 (CRC)	CRC
9-63	Reserved
64 (CRC 2)	unused

Response

Byte	Function
1 (header)	Header (0xAA)
2 (CMD)	0x85
3	0xF0 - Clear buffer
4-6	Reserved

7	Request ID
8 (CRC)	CRC
9-63	reserved
64 (CRC 2)	unused

*0x85/0xFF Fill motion buffer - 8-bit mode (max. 127 steps per slot)*

Request

Byte	Function
1 (header)	Header (0xBB)
2 (CMD)	0x85
3	0xFF - fill buffer: 8-bit mode
4	Number of new slots
5	Number of axes in buffer mode
6	Reserved
7	Request ID
8 (CRC)	CRC
9-64	Data (56 bytes) 8 axes = max. 7 slots 7 axes = max. 8 slots 6 axes = max. 9 slots 5 axes = max. 11 slots 4 axes = max. 14 slots 3 axes = max. 18 slots 2 axes = max. 28 slots 1 axis = max. 56 slots

Response (same as get status report, except for byte 3)

Byte	Function
1 (header)	Header (0xAA)
2 (CMD)	0x85
3	Number of accepted slots
4	Soft limit status (bit-mapped, one bit per axis)
5	States with enabled power
6	Limit override status
7	Request ID
8 (CRC)	CRC
9-63	See 'Get status' command report
64 (CRC 2)	unused

### 0xB0/0x85 Fill motion buffer via multi-part packet

Request - each packet in series of 8 packets

Byte	Function																
<b>1 (header)</b>	Header (0xBB)																
<b>2 (CMD)</b>	<b>0xB0</b>																
<b>3</b>	Multi-part index, flags <table border="1" style="margin-left: 40px;"> <thead> <tr> <th>Bit 7</th> <th>Bit 6</th> <th>Bit 5</th> <th>Bit 4</th> <th>Bit 3</th> <th>Bit 2</th> <th>Bit 1</th> <th>Bit 0</th> </tr> </thead> <tbody> <tr> <td>Reserved</td> <td>Reserved</td> <td>Reserved</td> <td>Stop bit</td> <td>Start bit</td> <td colspan="3">Packet index (0-7)</td> </tr> </tbody> </table>	Bit 7	Bit 6	Bit 5	Bit 4	Bit 3	Bit 2	Bit 1	Bit 0	Reserved	Reserved	Reserved	Stop bit	Start bit	Packet index (0-7)		
Bit 7	Bit 6	Bit 5	Bit 4	Bit 3	Bit 2	Bit 1	Bit 0										
Reserved	Reserved	Reserved	Stop bit	Start bit	Packet index (0-7)												
<b>4 (only first packet)</b>	0xFF - fill buffer: 8-bit mode 0xFE - fill buffer: 16-bit mode																
<b>5 (only first packet)</b>	Number of new slots																
<b>6 (only first packet)</b>	Number of axes in buffer mode																
<b>7</b>	Request ID																
<b>8 (CRC)</b>	CRC																
<b>9-64</b>	Data (56 bytes) from each packet is combined into final buffer, which is then inserted into motion buffer																

Response (same as get status report, except for byte 3)

Byte	Function
<b>1 (header)</b>	Header (0xAA)
<b>2 (CMD)</b>	<b>0xB0</b>
<b>3</b>	Number of accepted slots
<b>4</b>	Soft limit status (bit-mapped, one bit per axis)
<b>5</b>	States with enabled power
<b>6</b>	Limit override status
<b>7</b>	Request ID
<b>8 (CRC)</b>	CRC
<b>9-63</b>	See 'Get status' command report
<b>64 (CRC 2)</b>	unused

### *0x85/0xE0 Transfer RAW data*

Request

Byte	Function
1 (header)	Header (0xBB)
2 (CMD)	0x85
3	Number of bytes in payload
4	Last part of data (1)
5-6	Reserved
7	Request ID
8 (CRC)	CRC
9-64	Payload (up to 56 bytes)

Response (same as get status report, except for byte 3)

Byte	Function
1 (header)	Header (0xAA)
2 (CMD)	0x85
3	Status
4-6	Reserved
7	Request ID
8 (CRC)	CRC
9-64 (CRC 2)	unused

### *0x85/0x90 Read smart pulse generator configuration*

Request

Byte	Function
1 (header)	Header (0xBB)
2 (CMD)	0x85
3	0x90 - Read smart pulse generator configuration
4	Reserved
5	Reserved
6	Reserved
7	Request ID
8 (CRC)	CRC
9-63	Reserved
64 (CRC 2)	unused

Response

Byte	Function
1 (header)	Header (0xAA)
2 (CMD)	0x85
3	0x90 - Configure smart pulse generator
4-6	Reserved
7	Request ID
8 (CRC)	CRC
9-16	Pulse widths
17-24	Step pulse multiplication factors
25-32	Encoder pulse multiplication factors
33-48	Maximum mismatch value
49-52	Spindle PWM period

53	Pulse engine enabled - number of enabled axes
54	Encoder configurations
55	Encoder count mode
56-63	reserved
64 (CRC 2)	unused

### *0x85/0x91 Configure smart pulse generator*

Request

Byte	Function
1 (header)	Header (0xBB)
2 (CMD)	0x85
3	0x91 - Configure smart pulse generator
4	Reserved
5	Reserved
6	Reserved
7	Request ID
8 (CRC)	CRC
9-16	Pulse widths
17-24	Step pulse multiplication factors
25-32	Encoder pulse multiplication factors
33-48	Maximum mismatch value
49-52	Spindle PWM period
53	Pulse engine enabled - number of enabled axes
54	Encoder configurations
55	Encoder count mode
56-63	Reserved
64 (CRC 2)	unused

Response

Byte	Function
1 (header)	Header (0xAA)
2 (CMD)	0x85
3	0x91 - Configure smart pulse generator
4	Command result (0 - OK)
5	Reserved
6	Reserved
7	Request ID
8 (CRC)	CRC
9-63	reserved
64 (CRC 2)	unused

### *0x85/0x92 Reset smart pulse generator counters*

Request

Byte	Function
1 (header)	Header (0xBB)
2 (CMD)	0x85
3	0x92 - Reset smart pulse generator counters
4	bit mapped axes registers to reset
5	Reserved
6	Reserved

7	Request ID
8 (CRC)	CRC
9-63	Reserved
64 (CRC 2)	unused

Response

Byte	Function
1 (header)	Header (0xAA)
2 (CMD)	0x85
3	0x92 - Reset smart pulse generator counters
4	Command result (0 - OK)
5	Reserved
6	Reserved
7	Request ID
8 (CRC)	CRC
9-63	reserved
64 (CRC 2)	unused

### *0x85/0x95 Read smart pulse generator status*

Request

Byte	Function
1 (header)	Header (0xBB)
2 (CMD)	0x85
3	0x95 - Read smart pulse generator status
4	Reserved
5	Reserved
6	Reserved
7	Request ID
8 (CRC)	CRC
9-63	Reserved
64 (CRC 2)	unused

Response

Byte	Function
1 (header)	Header (0xAA)
2 (CMD)	0x85
3	0x95 - Read smart pulse generator status
4-6	Reserved
7	Request ID
8 (CRC)	CRC
9	Axis position mismatch statuses
10-11	Spindle rotation period
12	Input statuses
13-28	Current mismatch values
29-60	Current position values
61-63	reserved
64 (CRC 2)	unused

### *0x85/0x96 Read smart pulse generator encoder positions*

Request

Byte	Function
<b>1 (header)</b>	Header (0xBB)
<b>2 (CMD)</b>	<b>0x85</b>
<b>3</b>	0x96 - Read smart pulse generator encoder positions
<b>4</b>	Reserved
<b>5</b>	Reserved
<b>6</b>	Reserved
<b>7</b>	Request ID
<b>8 (CRC)</b>	CRC
<b>9-63</b>	Reserved
<b>64 (CRC 2)</b>	unused

Response

Byte	Function
<b>1 (header)</b>	Header (0xAA)
<b>2 (CMD)</b>	<b>0x85</b>
<b>3</b>	0x96 - Read smart pulse generator encoder positions
<b>4-6</b>	Reserved
<b>7</b>	Request ID
<b>8 (CRC)</b>	CRC
<b>9-40</b>	Current encoder positions
<b>41-63</b>	reserved
<b>64 (CRC 2)</b>	unused

### *0x85/0x30 Prepare trigger for threading*

This commands tells PoKeys device to empty the motion buffer, switch to spindle-synchronized motion and pause.

Request

Byte	Function
1 (header)	Header (0xBB)
2 (CMD)	0x85
3	0x30 - Prepare trigger
4-6	Reserved
7	Request ID
8 (CRC)	CRC
9-63	Reserved
64 (CRC 2)	unused

### *0x85/0x31 Force trigger prepare for threading*

This commands tells PoKeys device to switch to spindle-synchronized motion and pause immediately.

Request

Byte	Function
1 (header)	Header (0xBB)
2 (CMD)	0x85
3	0x31 - Force trigger prepare
4-6	Reserved
7	Request ID
8 (CRC)	CRC
9-63	Reserved
64 (CRC 2)	unused

### *0x85/0x32 Arm the trigger*

PoKeys will resume motion on the next index impulse of the ultra fast encoder in synchronization with the spindle.

Request

Byte	Function
1 (header)	Header (0xBB)
2 (CMD)	0x85
3	0x32 - Arm the trigger
4-6	Reserved
7	Request ID
8 (CRC)	CRC
9-63	Reserved
64 (CRC 2)	unused

### *0x85/0x33 Release the trigger*

This commands tells PoKeys device to disable spindle synchronization. PoKeys device uses smooth transition back to normal operating speed.

Request

Byte	Function
1 (header)	Header (0xBB)
2 (CMD)	0x85
3	0x33 - Release the trigger
4-6	Reserved
7	Request ID
8 (CRC)	CRC
9-63	Reserved
64 (CRC 2)	unused

### *0x85/0x34 Cancel threading mode*

Cancel the threading mode - go back into normal operating mode, restart motion if still waiting for the trigger.

Request

Byte	Function
1 (header)	Header (0xBB)
2 (CMD)	0x85
3	0x34 - Cancel threading mode
4-6	Reserved
7	Request ID
8 (CRC)	CRC
9-63	Reserved
64 (CRC 2)	unused

### *0x85/0x35 Get threading mode status*

Request

Byte	Function
1 (header)	Header (0xBB)
2 (CMD)	0x85
3	0x35 - Get threading mode status
4-6	Reserved
7	Request ID
8 (CRC)	CRC
9-63	Reserved
64 (CRC 2)	unused

Response

Byte	Function
1 (header)	Header (0xAA)
2 (CMD)	0x85
3	0x35 - Get threading mode status
4-6	Reserved
7	Request ID
8 (CRC)	CRC
9	Trigger preparing flag
10	Trigger prepared flag
11	Trigger waiting flag

12	Threading mode active
13-16	Estimated spindle velocity
17-20	Current rotor position error
21-24	Spindle RPM (sensor modes 2 and 3)
21-63	reserved
64 (CRC 2)	unused

### *0x85/0x36 Set threading mode parameters*

Request

Byte	Function
1 (header)	Header (0xBB)
2 (CMD)	0x85
3	0x36 - Set threading mode parameters
4-6	Reserved
7	Request ID
8 (CRC)	CRC
9	Spindle sensor mode (0 - index signal, 1 - encoder+index signal, 2 - high-speed spindle index signal (milling), 3 - high-speed encoder (milling))
13-14	Encoder ticks per rotation
15-16	Target spindle speed in rpm (revolutions per minute)
17-18	Spindle filter - speed error gain
19-20	Spindle filter - position error gain
17-63	Reserved
64 (CRC 2)	unused

Response

Byte	Function
1 (header)	Header (0xAA)
2 (CMD)	0x85
3	0x36 - Set threading mode parameters
4-6	Reserved
7	Request ID
8 (CRC)	CRC
9	Trigger preparing flag
10	Trigger prepared flag
11	Trigger waiting flag
12	Threading mode active
13-16	Estimated spindle velocity
17-20	Current rotor position error
21-24	Spindle RPM (sensor modes 2 and 3)
21-63	reserved
64 (CRC 2)	unused

## Backlash compensation

PoKeys Pulse engine v2 (PoKeys57 firmware 4.1.26 onwards) supports backlash compensation. For each direction change,  $2*W$  ( $W$  is half of backlash width in pulses) of pulses is additionally generated using the additional motion profile, that is configured using the acceleration setting only.

PoKeys device holds an additional register for backlash compensation that is transparent to the application using the Pulse engine (the value of the register is available in 0x85/0x40 command).

The acceleration value (integer) specifies the motion profile acceleration in pulses per  $ms^2$  (multiply this value by  $10^6$  to obtain the acceleration in pulses per  $s^2$ ).

### 0x85/0x40 Get backlash compensation settings

Request

Byte	Function
1 (header)	Header (0xBB)
2 (CMD)	0x85
3	0x40 - Get backlash compensation settings
4-6	Reserved
7	Request ID
8 (CRC)	CRC
9-63	Reserved
64 (CRC 2)	unused

Response

Byte	Function
1 (header)	Header (0xAA)
2 (CMD)	0x85
3	0x40 - Get backlash compensation settings
4	Backlash compensation enabled
5-6	Reserved
7	Request ID
8 (CRC)	CRC
9-10	Half of backlash width (16-bit, LSB first) - axis 1
11	Backlash acceleration (8-bit) - axis 1
12	Reserved - axis 1
13-40	Backlash settings for other axes (same structure as above)
41-56	State of the backlash compensation for each axis (signed 16-bit per axis)
57-63	reserved
64 (CRC 2)	unused

### 0x85/0x41 Set backlash compensation settings

Request

Byte	Function
1 (header)	Header (0xBB)
2 (CMD)	0x85
3	0x41 - Set backlash compensation settings
4	Backlash compensation enabled
4-6	Reserved
7	Request ID

<b>8 (CRC)</b>	CRC
<b>9-10</b>	Half of backlash width (16-bit, LSB first) - axis 1
<b>11</b>	Backlash acceleration (8-bit) - axis 1
<b>12</b>	Reserved - axis 1
<b>13-40</b>	Backlash settings for other axes (same structure as above)
<b>41-63</b>	reserved
<b>64 (CRC 2)</b>	unused

Response

Byte	Function
<b>1 (header)</b>	Header (0xAA)
<b>2 (CMD)</b>	<b>0x85</b>
<b>3</b>	0x41 - Set backlash compensation settings
<b>4</b>	Backlash compensation enabled
<b>5-6</b>	Reserved
<b>7</b>	Request ID
<b>8 (CRC)</b>	CRC
<b>9-10</b>	Half of backlash width (16-bit, LSB first) - axis 1
<b>11</b>	Backlash acceleration (8-bit) - axis 1
<b>12</b>	Reserved - axis 1
<b>13-40</b>	Backlash settings for other axes (same structure as above)
<b>41-56</b>	State of the backlash compensation for each axis (signed 16-bit per axis)
<b>41-63</b>	reserved
<b>64 (CRC 2)</b>	unused

## PoStep driver interface

PoKeys Pulse engine v2 (PoKeys57 firmware 4.1.42 onwards, limited to PoKeys57CNC) can talk directly to selected PoStep drivers (PoStep60-256) to bring the live driver status and ability to configure the driver directly via PoKeys device.

Drivers and PoKeys device have to be connected via a PoExtension cable (using 10-pin red connector). Multiple PoStep devices can be connected to PoKeys57CNC device by a means of 'hopping' connector (PoExtension connectors are pressed onto multiple positions along the 10-pin flat cable - all connected in parallel).

Each PoStep driver must initially be assigned with a unique I2C address using the PoStep configuration application.

The following status is available for each PoStep driver:

- Supply voltage
- Driver temperature
- Inputs statuses (bit-mapped)
  - o Bit 0: Bootloader override
  - o Bit 1: Sleep
  - o Bit 2: Step / AIN1
  - o Bit 3: Direction / AIN2
  - o Bit 4: BIN1
  - o Bit 5: BIN2
  - o Bit 6: End switch
  - o Bit 7: reserved
- Driver status (status value as below)
  - o 1: Driver in sleep mode
  - o 2: Driver active
  - o 3: Driver in idle mode
  - o 4: Driver overheated
  - o 5: Driver in DC motor control mode
- Faults status (bit-mapped)
  - o Bit 0: OTS - Device has entered over temperature shutdown. OTS bit will clear once temperature has fallen to safe levels
  - o Bit 1: AOCP - Channel A overcurrent shutdown. Check wiring or possible short circuit.
  - o Bit 2: BOCP - Channel B overcurrent shutdown. Check wiring or possible short circuit.
  - o Bit 3: APDF - Channel A predriver fault. Check driver settings.
  - o Bit 4: BPDF - Channel B predriver fault. Check driver settings.
  - o Bit 5: UVLO - Power supply voltage too low. Bit clears after voltage rises above lower limit.
  - o Bit 6: STD - Stall detected.
  - o Bit 7: STDLAT - Latched stall detect.

The following configuration can be changed:

- Driver mode:
  - o 1 Default mode – external control
  - o 2 Step control
  - o 3 DC motor control
  - o 4 Position control
  - o 5 BINx buttons
- Step mode:
  - o 0 Full step
  - o 1 Half step
  - o 2 1/4 step
  - o 3 1/8 step
  - o 4 1/16 step
  - o 5 1/32 step
  - o 6 1/64 step
  - o 7 1/128 step
  - o 8 1/256 step

- Temperature limit
- Full-scale current
- Idle current
- Overheat current

The PoKeys device communicates with PoStep devices asynchronously with PC - PoKeys device communication:

1. A instruction is given to PoKeys device to fetch or configure selected parameter
2. PoKeys executed the instruction when possible
3. Retrieved parameter's value is available in PoKeys device

Driver update configuration

PoKeys device can be configured to fetch selected driver status information automatically.

### *0x85/0x50 Setup driver communication*

Request

Byte	Function
<b>1 (header)</b>	Header (0xBB)
<b>2 (CMD)</b>	<b>0x85</b>
<b>3</b>	0x50 - Setup driver communication
<b>4</b>	Command (0 - read configuration, 0x10 - set configuration)
<b>5</b>	Enable driver communication
<b>6</b>	Reserved
<b>7</b>	Request ID
<b>8 (CRC)</b>	CRC
<b>9</b>	Axis 1 driver type
<b>10</b>	Axis 1 driver I2C address
<b>11</b>	Axis 1 driver update configuration  Bits 6-7: operation mode (0 - normal, 2 - write) Bit 5: Retrieve all parameters mode Bits 0-4: Parameters status bits each is bit-mapped to indicate which parameter should be retrieved (normal mode) bit 0: supply voltage bit 1: driver's temperature bit 2: input pin status bit 3: driver's status bit 4: faults status  Bits 0-4 in write mode: - 6: setup step mode - 7: setup temperature limit - 8: setup full-scale current - 9: setup idle current - 10: setup overheat current - 11: Save settings to EEPROM
<b>12-32</b>	Axes 2-8 driver types, I2C addresses and update configurations
<b>33-63</b>	Reserved
<b>64 (CRC 2)</b>	unused

Response

Byte	Function
------	----------

<b>1 (header)</b>	Header (0xAA)
<b>2 (CMD)</b>	<b>0x85</b>
<b>3</b>	0x50 - Setup driver communication
<b>4</b>	Command
<b>5</b>	Enable driver communication status
<b>6</b>	Reserved
<b>7</b>	Request ID
<b>8 (CRC)</b>	CRC
<b>9</b>	Axis 1 driver type
<b>10</b>	Axis 1 driver I2C address
<b>11</b>	Axis 1 driver update configuration
<b>12-32</b>	Axes 2-8 driver types, I2C addresses and update configurations
<b>33-63</b>	Reserved
<b>64 (CRC 2)</b>	unused

### *0x85/0x51 Get drivers' statuses*

Request

Byte	Function
<b>1 (header)</b>	Header (0xBB)
<b>2 (CMD)</b>	<b>0x85</b>
<b>3</b>	0x51 - Get drivers' statuses
<b>4-6</b>	Reserved
<b>7</b>	Request ID
<b>8 (CRC)</b>	CRC
<b>9-63</b>	reserved
<b>64 (CRC 2)</b>	unused

Response

Byte	Function
<b>1 (header)</b>	Header (0xAA)
<b>2 (CMD)</b>	<b>0x85</b>
<b>3</b>	0x51 - Get drivers' statuses
<b>4-6</b>	Reserved
<b>7</b>	Request ID
<b>8 (CRC)</b>	CRC
<b>9</b>	Axis 1: Supply voltage (in 0.25 V / unit)
<b>10</b>	Axis 1: Temperature (degrees C)
<b>11</b>	Axis 1: Input status
<b>12</b>	Axis 1: Driver status
<b>13</b>	Axis 1: Fault status
<b>14</b>	Axis 1: Update counter
<b>15-56</b>	Statuses from bytes 9-14 repeated for axes 2 - 8
<b>57-63</b>	reserved
<b>64 (CRC 2)</b>	unused

### *0x85/0x52 Get/Set driver's current parameters*

Request

Byte	Function
<b>1 (header)</b>	Header (0xBB)
<b>2 (CMD)</b>	<b>0x85</b>
<b>3</b>	0x52 - Get/Set driver's parameters
<b>4</b>	Command (0 - read configuration, 0x10 - set configuration)
<b>5-6</b>	Reserved
<b>7</b>	Request ID
<b>8 (CRC)</b>	CRC
<b>9-10</b>	Full-scale current setting - axis 1 driver
<b>11-12</b>	Idle current setting - axis 1 driver
<b>13-14</b>	Overheat current setting - axis 1 driver
<b>15-56</b>	Settings for axes 2-8, with the structure as above
<b>57-63</b>	Reserved
<b>64 (CRC 2)</b>	unused

Response

Byte	Function
<b>1 (header)</b>	Header (0xAA)
<b>2 (CMD)</b>	<b>0x85</b>
<b>3</b>	0x52 - Get/Set driver's parameters
<b>4</b>	Command
<b>5-6</b>	Reserved
<b>7</b>	Request ID
<b>8 (CRC)</b>	CRC
<b>9-10</b>	Full-scale current setting - axis 1 driver
<b>11-12</b>	Idle current setting - axis 1 driver
<b>13-14</b>	Overheat current setting - axis 1 driver
<b>15-56</b>	Settings for axes 2-8, with the structure as above
<b>57-63</b>	Reserved
<b>64 (CRC 2)</b>	unused

### *0x85/0x53 Get/Set driver's mode parameters and temperature limit*

Request

Byte	Function
<b>1 (header)</b>	Header (0xBB)
<b>2 (CMD)</b>	<b>0x85</b>
<b>3</b>	0x53 - Get/Set driver's mode parameters
<b>4</b>	Command (0 - read configuration, 0x10 - set configuration)
<b>5-6</b>	Reserved
<b>7</b>	Request ID
<b>8 (CRC)</b>	CRC
<b>9</b>	Driver mode setting - axis 1 driver
<b>10</b>	Driver step mode setting - axis 1 driver
<b>11</b>	Driver temperature limit setting - axis 1 driver
<b>12-14</b>	reserved
<b>15-56</b>	Settings for axes 2-8, with the structure as above
<b>57-63</b>	Reserved
<b>64 (CRC 2)</b>	unused

Response

Byte	Function
<b>1 (header)</b>	Header (0xAA)
<b>2 (CMD)</b>	<b>0x85</b>
<b>3</b>	0x53 - Get/Set driver's mode parameters
<b>4</b>	Command
<b>5-6</b>	Reserved
<b>7</b>	Request ID
<b>8 (CRC)</b>	CRC
<b>9</b>	Driver mode setting - axis 1 driver
<b>10</b>	Driver step mode setting - axis 1 driver
<b>11</b>	Driver temperature limit setting - axis 1 driver
<b>12-14</b>	reserved
<b>15-56</b>	Settings for axes 2-8, with the structure as above
<b>57-63</b>	Reserved
<b>64 (CRC 2)</b>	unused





## Failsafe mode

This settings give an option to set the outputs of the device to a predefined state after a preset communication timeout occurs.

### Basic settings

Byte	Function																
<b>1 (header)</b>	Header (0xBB)																
<b>2 (CMD)</b>	<b>0x81</b>																
<b>3</b>	Read (0) / Write (1) failsafe configuration																
<b>4</b>	Failsafe timeout (100 ms resolution) – 0 disables failsafe																
<b>5</b>	Enabled failsafe peripherals <table border="1" data-bbox="354 640 1406 741" style="margin-left: 40px;"> <thead> <tr> <th>Bit 7</th> <th>Bit 6</th> <th>Bit 5</th> <th>Bit 4</th> <th>Bit 3</th> <th>Bit 2</th> <th>Bit 1</th> <th>Bit 0</th> </tr> </thead> <tbody> <tr> <td>Reserved</td> <td>Reserved</td> <td>Reserved</td> <td>Reserved</td> <td>Pulse engine</td> <td>PWM</td> <td>PoExtBus</td> <td>Digital IO</td> </tr> </tbody> </table>	Bit 7	Bit 6	Bit 5	Bit 4	Bit 3	Bit 2	Bit 1	Bit 0	Reserved	Reserved	Reserved	Reserved	Pulse engine	PWM	PoExtBus	Digital IO
Bit 7	Bit 6	Bit 5	Bit 4	Bit 3	Bit 2	Bit 1	Bit 0										
Reserved	Reserved	Reserved	Reserved	Pulse engine	PWM	PoExtBus	Digital IO										
<b>6</b>	Reserved																
<b>7</b>	Request ID																
<b>8 (CRC)</b>	CRC																
<b>9-15</b>	Bit-mapped digital outputs state																
<b>16-25</b>	Bit-mapped PoExtBus outputs state																
<b>26-31</b>	PWM outputs duties (0-100 %)																
<b>32-63</b>	Reserved																
<b>64 (CRC 2)</b>	CRC																

### Basic settings - Response

Byte	Function																
<b>1 (header)</b>	Header (0xAA)																
<b>2 (CMD)</b>	<b>0x81</b>																
<b>3</b>	Read (0) / Write (1) failsafe configuration request value																
<b>4</b>	Failsafe timeout (100 ms resolution) – 0 disables failsafe																
<b>5</b>	Enabled failsafe peripherals <table border="1" data-bbox="354 1435 1406 1536" style="margin-left: 40px;"> <thead> <tr> <th>Bit 7</th> <th>Bit 6</th> <th>Bit 5</th> <th>Bit 4</th> <th>Bit 3</th> <th>Bit 2</th> <th>Bit 1</th> <th>Bit 0</th> </tr> </thead> <tbody> <tr> <td>Reserved</td> <td>Reserved</td> <td>Reserved</td> <td>Reserved</td> <td>Pulse engine</td> <td>PWM</td> <td>PoExtBus</td> <td>Digital IO</td> </tr> </tbody> </table>	Bit 7	Bit 6	Bit 5	Bit 4	Bit 3	Bit 2	Bit 1	Bit 0	Reserved	Reserved	Reserved	Reserved	Pulse engine	PWM	PoExtBus	Digital IO
Bit 7	Bit 6	Bit 5	Bit 4	Bit 3	Bit 2	Bit 1	Bit 0										
Reserved	Reserved	Reserved	Reserved	Pulse engine	PWM	PoExtBus	Digital IO										
<b>6</b>	Reserved																
<b>7</b>	Request ID																
<b>8 (CRC)</b>	CRC																
<b>9-15</b>	Bit-mapped digital outputs state																
<b>16-25</b>	Bit-mapped PoExtBus outputs state																
<b>26-31</b>	PWM outputs duties (0-100 %)																
<b>32-63</b>	Reserved																
<b>64 (CRC 2)</b>	CRC																

## PoIL commands

See PoIL.pdf for description of the PoIL core.

### 0x82/0x00 PoIL core status

Byte	Function
1 (header)	Header (0xBB)
2 (CMD)	0x82
3	0x00 – get PoIL core status
4-6	Reserved
7	Request ID
8 (CRC)	CRC
9-63	Reserved
64 (CRC 2)	CRC

PoIL core status - Response

Byte	Function
1 (header)	Header (0xAA)
2 (CMD)	0x82
3	0x00 – get PoIL core status
4-6	Reserved
7	Request ID
8 (CRC)	CRC
9-10	Code memory size
11-12	Data memory size
13	Version
14-15	Current PoIL core state
16	PoIL core debug mode
17	Current task
18-19	PoIL core debug breakpoint
20-21	Current PC value
22	Current STATUS register value
23-26	Current W register value
27-28	Exception PC
29-30	Current function stack pointer
31-32	Current data stack pointer
60	PoIL master enable status
61	Number of PoIL tasks
33-63	reserved
64 (CRC 2)	CRC

### 0x82/0x01 Set PoIL core state

Byte	Function
1 (header)	Header (0xBB)
2 (CMD)	0x82
3	0x01 – set PoIL core state
4-5	PoIL core state
6	Reserved
7	Request ID

<b>8 (CRC)</b>	CRC
<b>9-63</b>	Reserved
<b>64 (CRC 2)</b>	CRC

Response contents is similar to »PoIL core status – Response«.

#### *0x82/0x02 Reset PoIL processor*

Byte	Function
<b>1 (header)</b>	Header (0xBB)
<b>2 (CMD)</b>	<b>0x82</b>
<b>3</b>	0x02 – Reset processor
<b>6</b>	Reserved
<b>7</b>	Request ID
<b>8 (CRC)</b>	CRC
<b>9-63</b>	Reserved
<b>64 (CRC 2)</b>	CRC

Response contents is similar to »PoIL core status – Response«.

#### *0x82/0x03 Set PoIL master enable status*

Byte	Function
<b>1 (header)</b>	Header (0xBB)
<b>2 (CMD)</b>	<b>0x82</b>
<b>3</b>	0x03 – set PoIL master enable
<b>4</b>	PoIL master enable value
<b>5-6</b>	Reserved
<b>7</b>	Request ID
<b>8 (CRC)</b>	CRC
<b>9-63</b>	Reserved
<b>64 (CRC 2)</b>	CRC

Response contents is similar to »PoIL core status – Response«.

#### *0x82/0x05 Set PoIL debug mode*

Byte	Function
<b>1 (header)</b>	Header (0xBB)
<b>2 (CMD)</b>	<b>0x82</b>
<b>3</b>	0x05 – set PoIL core debug mode
<b>4</b>	PoIL core debug mode 0 - debug STOP mode 10 - running to breakpoint 11 - run to breakpoint 20 - one instruction
<b>5-6</b>	Breakpoint address
<b>7</b>	Request ID
<b>8 (CRC)</b>	CRC
<b>9-63</b>	Reserved
<b>64 (CRC 2)</b>	CRC

Response contents is similar to »PoLL core status – Response«.

### *0x82/0x10 PoLL memory read*

This command reads a chunk of up to 55 bytes from the selected memory

Byte	Function
<b>1 (header)</b>	Header (0xBB)
<b>2 (CMD)</b>	<b>0x82</b>
<b>3</b>	0x10 – PoLL memory read
<b>4</b>	Memory selection (0 – code, 1 – data, 2 – code stack, 3 – data stack, 4 - shared data, 5 - internal addressing used)
<b>5-6</b>	Memory address (or shared data index)
<b>7</b>	Request ID
<b>8 (CRC)</b>	CRC
<b>9</b>	Memory chunk size
<b>10-63</b>	Reserved
<b>64 (CRC 2)</b>	CRC

PoLL memory read - Response

Byte	Function
<b>1 (header)</b>	Header (0xAA)
<b>2 (CMD)</b>	<b>0x82</b>
<b>3</b>	0x10 – read memory
<b>4-6</b>	Reserved
<b>7</b>	Request ID
<b>8 (CRC)</b>	CRC
<b>9-63</b>	Memory contents
<b>64 (CRC 2)</b>	CRC

### *0x82/0x11 PoLL memory read – monitor mode*

This command reads multiple chunks of up to 55 bytes from the selected memory (only data memory allowed)

Byte	Function
<b>1 (header)</b>	Header (0xBB)
<b>2 (CMD)</b>	<b>0x82</b>
<b>3</b>	0x11 – PoLL memory read (monitor)
<b>4</b>	Memory selection (1 – data, 5 - internal addressing, other sources not allowed)
<b>5-6</b>	reserved
<b>7</b>	Request ID
<b>8 (CRC)</b>	CRC
<b>9-10</b>	Chunk 1 address
<b>11</b>	Chunk 1 size
<b>12-13</b>	Chunk 2 address (set to FFFF to stop reading)
<b>14</b>	Chunk 2 size
...	
<b>60-61</b>	Chunk 18 address
<b>62</b>	Chunk 18 size
<b>63</b>	Reserved
<b>64 (CRC 2)</b>	CRC

PoLL memory read - Response

Byte	Function
<b>1 (header)</b>	Header (0xAA)
<b>2 (CMD)</b>	<b>0x82</b>
<b>3</b>	0x11 – PoIL memory read (monitor)
<b>4-6</b>	Reserved
<b>7</b>	Request ID
<b>8 (CRC)</b>	CRC
<b>9-63</b>	Memory contents by chunks of data
<b>64 (CRC 2)</b>	CRC

### *0x82/0x15 PoIL memory write*

This command writes a chunk of up to 54 bytes to the selected memory. If code memory is selected, data memory locations 0-255 are used as data source and must be filled with correct data prior to this call. Code memory write always writes 256 bytes at a time.

Byte	Function
<b>1 (header)</b>	Header (0xBB)
<b>2 (CMD)</b>	<b>0x82</b>
<b>3</b>	0x15 – PoIL memory write
<b>4</b>	Memory selection (0 – code, 1 – data, 4 - shared data, 5 - internal addressing used)
<b>5-6</b>	Memory address (or shared data index)
<b>7</b>	Request ID
<b>8 (CRC)</b>	CRC
<b>9</b>	Memory chunk size
<b>10-63</b>	Memory contents
<b>64 (CRC 2)</b>	CRC

PoIL memory write - Response

Byte	Function
<b>1 (header)</b>	Header (0xAA)
<b>2 (CMD)</b>	<b>0x82</b>
<b>3</b>	0x15 – write memory
<b>4-6</b>	Reserved
<b>7</b>	Request ID
<b>8 (CRC)</b>	CRC
<b>9-63</b>	reserved
<b>64 (CRC 2)</b>	CRC

### *0x82/0x16 PoIL memory erase*

This command erases the selected PoIL memory

Byte	Function
<b>1 (header)</b>	Header (0xBB)
<b>2 (CMD)</b>	<b>0x82</b>
<b>3</b>	0x16 – PoIL memory erase
<b>4</b>	Memory selection (0 – code, 1 – data)
<b>5-6</b>	Reserved
<b>7</b>	Request ID
<b>8 (CRC)</b>	CRC
<b>9-63</b>	Reserved
<b>64 (CRC 2)</b>	CRC

PoIL memory erase - Response

Byte	Function
<b>1 (header)</b>	Header (0xAA)
<b>2 (CMD)</b>	<b>0x82</b>
<b>3</b>	0x16 – erase memory
<b>4-6</b>	Reserved
<b>7</b>	Request ID
<b>8 (CRC)</b>	CRC
<b>9-63</b>	reserved
<b>64 (CRC 2)</b>	CRC

*0x82/0x20 PoIL task status read*

This command retrieves the PoIL task statuses

Byte	Function
<b>1 (header)</b>	Header (0xBB)
<b>2 (CMD)</b>	<b>0x82</b>
<b>3</b>	0x20 – Read PoIL task status
<b>4</b>	First task index (t)
<b>5</b>	Number of tasks to include (max. 7, depends on system)
<b>6</b>	Reserved
<b>7</b>	Request ID
<b>8 (CRC)</b>	CRC
<b>9-63</b>	Reserved
<b>64 (CRC 2)</b>	CRC

Read PoIL task status - Response

Byte	Function
<b>1 (header)</b>	Header (0xAA)
<b>2 (CMD)</b>	<b>0x82</b>
<b>3</b>	0x20 – Read PoIL task status
<b>4</b>	System inactive load
<b>5-6</b>	Reserved
<b>7</b>	Request ID
<b>8 (CRC)</b>	CRC
<b>9+t*8</b>	Task status
<b>10+t*8</b>	Task load
<b>11-12 +t*8</b>	Configured task period
<b>13-14 +t*8</b>	Real task period - current
<b>15-16 +t*8</b>	Real task period - filtered

## RTC (Real Time Clock) setup

These commands are used to read or set the RTC clock, running in the device.

### 0x83 Read/Set current time

Byte	Function
1 (header)	Header (0xBB)
2 (CMD)	0x83
3	0x00 – read time, 0x10 – set time, 0x11 - set time and daylight saving time options
4-6	Reserved
7	Request ID
8 (CRC)	CRC
9	Second (0-59)
10	Minute (0-59)
11	Hour (0-23)
12	Day of week (0-6)
13	Day of month (1-31)
14	Month (1-12)
15-16	Day of year (1 – 365)
17-18	Year
19	Daylight saving time rule: 0: disabled 1: manually enabled 10: EU (from 01:00 UTC of last Sunday in March to 01:00 UTC of last Sunday in October) 20: US (from 02:00 AM of second Sunday in March to 02:00 AM of first Sunday in November) 30: AU (from 02:00 AM of first Sunday in November to 02:00 AM of first Sunday in April)
20	UTC offset for EU DST (signed 8-bit number) - supported values between -1 and 2
21-63	Reserved
64 (CRC 2)	CRC

### Read/set time - Response

Byte	Function
1 (header)	Header (0xAA)
2 (CMD)	0x83
3	Same as byte 3 in request
4-6	Reserved
7	Request ID
8 (CRC)	CRC
9	Second (0-59)
10	Minute (0-59)
11	Hour (0-23)
12	Day of week (0-6)
13	Day of month (1-31)
14	Month (1-12)
15-16	Day of year (1 – 365)
17-18	Year
19	Daytime saving time rule: 0: disabled 1: manually enabled 10: EU (from 01:00 UTC of last Sunday in March to 01:00 UTC of last Sunday in October) 20: US (from 02:00 AM of second Sunday in March to 02:00 AM of first Sunday in November) 30: AU (from 02:00 AM of first Sunday in November to 02:00 AM of first Sunday in April)

<b>20</b>	UTC offset for EU DST (signed 8-bit number) - supported values between -1 and 2
<b>21-63</b>	Reserved
<b>64 (CRC 2)</b>	CRC

## System event logging

### *0x84 Read/clear system log*

Byte	Function
1 (header)	Header (0xBB)
2 (CMD)	0x84
3	0x00 – read log, 0x10 – clear log
4-6	Reserved
7	Request ID
8 (CRC)	CRC
9-63	Reserved
64 (CRC 2)	CRC

### Read/set time - Response

Byte	Function
1 (header)	Header (0xAA)
2 (CMD)	0x84
3	Total number of log entries
4-6	Reserved
7	Request ID
8 (CRC)	CRC
9-62	27 Log entries (LSB first)
63	Reserved
64 (CRC 2)	CRC

### PPM decoder configuration and status

This command configures the PPM decoding option in PoKeys devices. PPM signal consist of series of pulses that encode the position information of up to 8 R/C servos. PoKeys detects the synchronisation pulse and extracts the commanded positions of each servo. This feature is available on PoKeys57U devices on pin 3 and on PoKeys57E devices on pin 24.

Unsupported devices: PoKeys55, PoKeys56 series

#### 0x09 PPM decoder configuration and status

Byte	Function
1 (header)	Header (0xBB)
2 (CMD)	0x09
3	0x00 – read configuration and status, 0x10 – set configuration
4	Configuration: bit 0: enable PPM decoding; bit 1: positive edge decoding
5-6	Reserved
7	Request ID
8 (CRC)	CRC
9-63	Reserved
64 (CRC 2)	CRC

Read/set time - Response

Byte	Function
1 (header)	Header (0xAA)
2 (CMD)	0x09
3	Configuration - see request header above
4-6	Reserved
7	Request ID
8 (CRC)	CRC
9-10	Decoded PPM data age in 0.1 ms
11-26	Decoded PPM data (8 channels, 2 bytes each, LSB first)
63	Reserved
64 (CRC 2)	CRC

## MCS (Multi Channel Servo) system configuration and control

PoKeys57 series devices support MCS system to generate PWM signals for R/C servo motors. The number of supported channels depend on the device type, but is typically limited by the number of digital output pins.

Each MCS channel can be configured with maximum acceleration and maximum velocity values, that are used for generating the changes of the PWM duty cycle values (if maximum velocity is set to 0, no motion planning is executed). The duty cycle of the PWM outputs is specified in microseconds, while the system operates at the resolution of 2 us.

MCS generates PWM signals in pulse batches of at least 10 outputs at a time (the exact number depends on the values of the PWM signals), so the system needs up to 6 pulse batches (each taking 2.5 ms to execute) in order to update all outputs. This results in minimum update period of 15 ms for all 55 outputs. Each PWM channel supports duty cycles between 100 and 2300 us.

Supported devices: PoKeys57E, PoKeys57U

### 0x4A/0x00 Read MCS status

Byte	Function
1 (header)	Header (0xBB)
2 (CMD)	0x4A
3	0x00 – read status
4-6	Reserved
7	Request ID
8 (CRC)	CRC
9-63	Reserved
64 (CRC 2)	CRC

### Read MCS status - Response

Byte	Function
1 (header)	Header (0xAA)
2 (CMD)	0x4A
3	0x00
4	MCS global enable
5-6	Reserved
7	Request ID
8 (CRC)	CRC
9-63	MCS channels statuses
64 (CRC 2)	CRC

### 0x4A/0x01 Set MCS status

Byte	Function
1 (header)	Header (0xBB)
2 (CMD)	0x4A
3	0x01 – set status
4	MCS global enable
5-6	Reserved
7	Request ID

<b>8 (CRC)</b>	CRC
<b>9-63</b>	MCS channels statuses
<b>64 (CRC 2)</b>	CRC

Set MCS status - Response

Byte	Function
<b>1 (header)</b>	Header (0xAA)
<b>2 (CMD)</b>	<b>0x4A</b>
<b>3</b>	0x00
<b>4</b>	MCS global enable
<b>5-6</b>	Reserved
<b>7</b>	Request ID
<b>8 (CRC)</b>	CRC
<b>9-63</b>	MCS channels statuses
<b>64 (CRC 2)</b>	CRC

*0x4A/0x10 Get MCS channel parameters*

Byte	Function
<b>1 (header)</b>	Header (0xBB)
<b>2 (CMD)</b>	<b>0x4A</b>
<b>3</b>	0x10 – get MCS channel parameters
<b>4</b>	Channel ID
<b>5-6</b>	Reserved
<b>7</b>	Request ID
<b>8 (CRC)</b>	CRC
<b>9-63</b>	reserved
<b>64 (CRC 2)</b>	CRC

Get MCS channel parameters - Response

Byte	Function
<b>1 (header)</b>	Header (0xAA)
<b>2 (CMD)</b>	<b>0x4A</b>
<b>3</b>	0x10
<b>4</b>	Channel ID
<b>5-6</b>	Reserved
<b>7</b>	Request ID
<b>8 (CRC)</b>	CRC
<b>9-12</b>	Maximum velocity (pulse us / period)
<b>13-16</b>	Maximum acceleration (pulse us / period <sup>2</sup> )
<b>17-18</b>	Minimum position (pulse us)
<b>19-20</b>	Maximum position (pulse us)
<b>21-22</b>	Default position (pulse us)
<b>23</b>	Failsafe / startup configuration
<b>24-63</b>	reserved
<b>64 (CRC 2)</b>	CRC

*0x4A/0x11 Set MCS channel parameters*

Byte	Function
------	----------

<b>1 (header)</b>	Header (0xBB)
<b>2 (CMD)</b>	<b>0x4A</b>
<b>3</b>	0x11 – set MCS channel parameters
<b>4</b>	Channel ID
<b>5-6</b>	Reserved
<b>7</b>	Request ID
<b>8 (CRC)</b>	CRC
<b>9-12</b>	Maximum velocity (pulse us / period)
<b>13-16</b>	Maximum acceleration (pulse us / period <sup>2</sup> )
<b>17-18</b>	Minimum position (pulse us)
<b>19-20</b>	Maximum position (pulse us)
<b>21-22</b>	Default position (pulse us)
<b>23</b>	Failsafe / startup configuration
<b>24-63</b>	reserved
<b>64 (CRC 2)</b>	CRC

#### Set MCS channel parameters - Response

Byte	Function
<b>1 (header)</b>	Header (0xAA)
<b>2 (CMD)</b>	<b>0x4A</b>
<b>3</b>	0x11
<b>4</b>	Channel ID
<b>5-6</b>	Reserved
<b>7</b>	Request ID
<b>8 (CRC)</b>	CRC
<b>9-12</b>	Maximum velocity (pulse us / period)
<b>13-16</b>	Maximum acceleration (pulse us / period <sup>2</sup> )
<b>17-18</b>	Minimum position (pulse us)
<b>19-20</b>	Maximum position (pulse us)
<b>21-22</b>	Default position (pulse us)
<b>23</b>	Failsafe / startup configuration
<b>24-63</b>	reserved
<b>64 (CRC 2)</b>	CRC

#### 0x4A/0x20 Read MCS rough positions

Byte	Function
<b>1 (header)</b>	Header (0xBB)
<b>2 (CMD)</b>	<b>0x4A</b>
<b>3</b>	0x20 – read rough positions
<b>4-6</b>	Reserved
<b>7</b>	Request ID
<b>8 (CRC)</b>	CRC
<b>9-63</b>	Reserved
<b>64 (CRC 2)</b>	CRC

#### Read MCS rough positions - Response

Byte	Function
<b>1 (header)</b>	Header (0xAA)
<b>2 (CMD)</b>	<b>0x4A</b>
<b>3</b>	0x20

<b>4-6</b>	Reserved
<b>7</b>	Request ID
<b>8 (CRC)</b>	CRC
<b>9-63</b>	MCS channels positions (0-255 in the specified minimum to maximum range)
<b>64 (CRC 2)</b>	CRC

*0x4A/0x21 Set MCS rough positions*

Byte	Function
<b>1 (header)</b>	Header (0xBB)
<b>2 (CMD)</b>	<b>0x4A</b>
<b>3</b>	0x21 – set rough positions
<b>4-6</b>	Reserved
<b>7</b>	Request ID
<b>8 (CRC)</b>	CRC
<b>9-63</b>	MCS channels positions (0-255 in the specified minimum to maximum range)
<b>64 (CRC 2)</b>	CRC

Set MCS rough positions - Response

Byte	Function
<b>1 (header)</b>	Header (0xAA)
<b>2 (CMD)</b>	<b>0x4A</b>
<b>3</b>	0x21
<b>4-6</b>	Reserved
<b>7</b>	Request ID
<b>8 (CRC)</b>	CRC
<b>9-63</b>	Reserved
<b>64 (CRC 2)</b>	CRC